



## Bathing establishment Fact Sheet

Name of bathing establishment	CROCE ROSSA
Address	Via Litoranea, 68
City	Marina di Pisa (PI)
Contacts	+39 050 983575 +39 050 36304 – <a href="mailto:pisa@cri.it">pisa@cri.it</a>
Website	<a href="https://www.cripisa.it">https://www.cripisa.it</a>

**TESTED BY:** [Handy Social Promotion Association Surpassable](#) in summer 2024

**Please note** The following information refers to the date of verification shown at the bottom of each sheet. **The Association** is not responsible for any significant changes made by the property after the visit.

### Summary

Bathing establishment Fact Sheet .....	1
Arrival at the property.....	2
Private/public parking.....	2
Pathway from the car park to the main entrance .....	3
Reception reception .....	3
Bar/restaurant .....	4
Internal pathways and common services .....	5
Internal pathways.....	5
Toilet and shower for guests with reduced mobility .....	7
Changing room .....	9
Beach.....	10
Children's play area .....	11
Swimming pool .....	12
Medical practices/healthcare facilities.....	12

Project carried out with the contribution of the





**Arrival at the property**



**Private/public parking**

Presence of private parking	YES
Type of private parking fund	Gravel and asphalt
Presence of parking space reserved for people with disabilities	YES number 7 in the first parking lot and number 4 in front of the entrance (where jet skis are temporarily positioned)
Public parking nearby	NO
	
	





### Pathway from the car park to the main entrance

Pathway from the car park to the entrance	The entrance can be reached from the car park via a path that in a first stretch is in gravel then asphalt, uphill for 35 m with a gradient of 10.5%.
There are indicators and tactile maps	NO
Useful width of door/entrance gate	Above 90 cm
	

### Reception reception

Umbrella booking system	<input type="checkbox"/> Via the web <input checked="" type="checkbox"/> By phone <input checked="" type="checkbox"/> On-site
Presence of multilingual staff	YES
Presence of plant map with legend of services available	NO
Presence of visuo-tactile map	NO





Bulletin board/information panels with an average height of 130 cm in a well-lit area and a font size of at least 14 dpi with a contrast ratio greater than 4.5:1	NO
The staff followed a training course on welcoming people with different disabilities	NO

### Bar/restaurant

Type of venue	Bar/restaurant /Self service
Access to the premises	Flat from the entrance. From the beach it can be reached via a first ramp 6.5 m long, > 90 cm wide, slope 7%. Parking shelf 8.7 m, ramp 4.4 m long, > 90 cm wide, slope 8 %, then flat for the entire cabin area until you reach ramp 25 m long, > 90 cm wide, slope 8.7%
Useful width of door/entrance gate	Above 90 cm
Bar bench	Above 100 cm - self-service counter 83 cm from the ground
Types of tables	4-legged
Space under floor tables	72.7 cm
Multilingual menu	YES
Large print menus	NO
Braille menu	NO
Table service for people with disabilities	YES
Availability of foods for celiacs	<input checked="" type="checkbox"/> bread <input checked="" type="checkbox"/> pasta <input checked="" type="checkbox"/> biscuits <input checked="" type="checkbox"/> ice cream <input checked="" type="checkbox"/> Pre-packaged foods





## Internal pathways and common services

### Internal pathways

Indicate whether the pathways connecting the entrance to the beach are flat or with ramps in addition to those already described

From the restaurant the beach can be reached by stairs. Externally, through a first ramp, 25 meters long, > to 90 cm wide, 8.7% slope, which leads to the cabins, bathrooms and changing rooms. To reach the beach, you have to overcome





	<p>a second ramp interrupted by a belay shelf 4.4 m + 8.7 m long (belay shelf), &gt; to 90 cm wide, 8% slope, additional 6.5 m ramp, &gt;90 wide, 7% slope</p>
	
	
	





### Toilet and shower for guests with reduced mobility

Number of <b>accessible toilets</b> for guests with reduced mobility	2
Access to the premises	The toilet near the restaurant can be reached on the flat. For the second bathroom, near the beach, the entrance is accessible via a 30 cm connecting ramp, slope 26%
Usable width of the entrance door	First bathroom > 90 cm. Second bathroom 90 cm
Toilet height	First bathroom 44 cm. Second bathroom 52 cm
Open front toilet seat	The first bath with an open front tooth, the second with a closed front tooth
Support handles	Both bathrooms on both sides
Flexible shower on the side of the toilet	YES in both bathrooms
Free space on the sides of the toilet	First bathroom, left Above 90 cm right 21 ,5 Cm frontal 7 9 Cm Second bathroom, left 29.6 cm Right and front > 90 cm
Electric doorbell/telephone	YES in both bathrooms
Washbasin with space underneath for wheelchair approach	First bathroom 79 cm, second bathroom 76.4 cm
Height from the ground lower edge mirror	In the first bathroom missing. Second bathroom sufficient for use by a person in a wheelchair
Baby changing table	NO



Project promoted by



Regione Toscana



Project carried out with the contribution of the



Presidenza del  
Consiglio dei Ministri  
Ministro per la disabilità



<p><b>Accessible shower</b> available for guests with reduced mobility</p>	<p>YES in common with the toilet room</p>
<p>Type of shower</p>	<p>open type</p>
<p>Floor-level shower</p>	<p>YES</p>
<p>Shower chair</p>	<p>Plastic chair with armrests</p>
<p>Support handle</p>	<p>YES</p>
<p>Presence of shower head or sliding rails</p>	<p>Hand shower</p>
<p>Electric doorbell/telephone</p>	<p>YES</p>

### Changing room

<p>Changing room accessible to guests with reduced mobility available</p>	<p>YES</p>
<p>Access to the premises</p>	<p>Same path for the toilet</p>
<p>Useful width of door/entrance gate</p>	<p>Above 90 cm .</p>
<p>Locker room size</p>	<p>width 150 cm and depth 144 cm .</p>
<p>Presence of cot</p>	<p>NO</p>
<p>Coat rack height from the ground</p>	<p>Above 140 cm</p>





## Beach

Type of beach	sand
Beach access	From the entrance, the beach can be reached externally via a first ramp, 25 meters long, > to 90 cm wide, 8.7% slope, which leads to the cabins, bathrooms and changing rooms. To reach the beach, you have to overcome a second ramp interrupted by a belay shelf 4.4 m + 8.7 m long (belay shelf), > to 90 cm wide, 8% slope, additional 6.5 m ramp, >90 wide, 7% slope
Walkway to reach the umbrellas	YES
Type of walkway	PVC
Width of the walkway	90 cm





<p>Removable Platform between the walkway and the umbrella station to facilitate the passage and parking wheelchair</p>	<p>YES</p>
<p>Amphibious beach chair available for helping people with reduced mobility to enjoy swimming (owned by the establishment or by association)</p>	<p>Number 4 Job chairs</p>

**Children's play area**

<p>Children's play area</p>	<p>missing</p>
-----------------------------	----------------





There are games for children with reduced mobility	NO
--	----

### Swimming pool

The property has a swimming pool	NO
----------------------------------	----

### Medical practices/healthcare facilities

Hospitals near the property	<p>For HEALTH EMERGENCIES 112 or 118 Azienda Ospedaliera Universitaria Pisana Emergency Room 050 992300 (it is active from 8.00 in the morning to 01.00 at night, after this time the Emergency Room can be contacted through the switchboard) Toll-free number 800.015877 Switchboard 050.992111 Santa Chiara Hospital Via Roma, 67 – Pisa (in the city center) Cisanello Hospital Via Paradisa, 2 - Cisanello - Pisa. On the eastern outskirts of Pisa</p>
Other healthcare facilities	<p>tourist medical guard for the Pisan coast via Flavio Andò 5 in Marina di Pisa every day from 10 to 13 and from 16 to 19, tel. 050 954681.</p>

**TESTED BY:** [Handy Social Promotion Association Surpassable](#) in summer 2024

