



## Bathing establishment Fact Sheet

Name of bathing establishment	LUANA
Address	Viale del Tirreno, 58
City	Tirrenia (PI)
Contacts	+ 39 050 37567 - +39 3933359920 <a href="mailto:bluana.tinghi@gmail.com">bluana.tinghi@gmail.com</a>
Website	<a href="https://bagnoluana.it/">https://bagnoluana.it/</a>

**T TESTED BY:** [Handy Social Promotion Association Surpassable](#) in summer 2024

**Please note** The following information refers to the date of verification shown at the bottom of each sheet. **The Association** is not responsible for any significant changes made by the property after the visit.

### Summary

Bathing establishment Fact Sheet .....	1
Arrival at the property.....	2
Private/public parking.....	2
Pathway from the car park to the main entrance .....	3
Reception reception .....	3
Bar/restaurant .....	4
Internal pathways and common services .....	5
Internal pathways.....	5
Toilet and shower for guests with reduced mobility .....	6
Changing room .....	9
Beach.....	9
Children's play area .....	10
Swimming pool .....	11

Project carried out with the contribution of the





Medical practices/healthcare facilities.....11

**Arrival at the property**

**Private/public parking**

Presence of private parking	YES
Type of private parking fund	Gravel
Presence of parking space reserved for people with disabilities	YES on call
Public parking nearby	YES
Type of public parking floor	asphalt





Project carried out with the contribution of the





**Pathway from the car park to the main entrance**

Pathway from the car park to the entrance	flat
There are indicators and tactile maps	NO
Useful width of door/entrance gate	Above 90 cm
	

**Reception reception**

Umbrella booking system	<input checked="" type="checkbox"/> Via the web <input checked="" type="checkbox"/> By phone <input checked="" type="checkbox"/> On-site
Presence of multilingual staff	YES
Presence of plant map with legend of services available	NO
Presence of visuo-tactile map	NO
Bulletin board/information panels with an average height of 130 cm in a well-lit area	NO






and a font size of at least 14 dpi with a contrast ratio greater than 4.5:1	
The staff followed a training course on welcoming people with different disabilities	NO

**Bar/restaurant**

Type of venue	Bar/restaurant /self service
Access to the premises	flat
Useful width of door/entrance gate	Above 90 cm
Bar bench	Above 100 cm , buffet counter 68.8 cm
Types of tables	4-legged
Space under floor tables	66 cm
Multilingual menu	NO
Large print menus	NO
Braille menu	NO
Table service for people with disabilities	YES
Availability of foods for celiacs	<input type="checkbox"/> bread <input type="checkbox"/> pasta <input type="checkbox"/> biscuits <input checked="" type="checkbox"/> ice cream <input checked="" type="checkbox"/> Pre-packaged foods






### Internal pathways and common services

#### Internal pathways

Indicate whether the pathways connecting the entrance to the beach are flat or with ramps in addition to those already described

Obstacle-free pathways with a ramp 6 m long, > 90 cm wide, gradient 14%. Ramp 3 m long, 90 cm wide, slope 10 %





**Toilet and shower for guests with reduced mobility**

Number of <b>accessible toilets</b> for guests with reduced mobility	2 Bathrooms. A (outside) and B (restaurant)
Access to the premises	flat
Usable width of the entrance door	At 85.8 cm. B 80.6 cm
Toilet height	At 53.3 cm . B 51.6 cm
Open front toilet seat	bathroom A NO, bathroom B YES
Support handles	on both sides for both bathrooms
Flexible shower on the side of the toilet	bathroom A No , bathroom B Yes
Free space on the sides of the toilet	A: left 22.4 cm right Above 90 cm frontal 77 cm B: left 20 cm on the right greater than 90 cm front over 90 cm
Electric doorbell/telephone	YES for both bathrooms
Washbasin with space underneath for wheelchair approach	A: 76.6 cm, bathroom B 79.9 cm





Height from the ground lower edge mirror	A: missing, B: usable by wheelchair users
Baby changing table	NO
	
	
	





<p><b>Accessible shower</b> available for guests with reduced mobility</p>	<p>YES shared with the toilet room for both bathrooms</p>
<p>Type of shower</p>	<p>Bathroom A open, bathroom B open but with shower tray 70 cm x 80 cm</p>
<p>Floor-level shower</p>	<p>Bathroom A YES, bathroom B with 3 cm shower tray</p>
<p>Shower chair</p>	<p>wall-mounted folding bathroom A, bathroom B missing</p>
<p>Support handle</p>	<p>NO both bathrooms</p>
<p>Presence of shower head or sliding rails</p>	<p>Both with ups and downs with the lowest point reachable by a seated person,</p>
<p>Electric doorbell/telephone</p>	<p>YES both</p>





### Changing room

Changing room accessible to guests with reduced mobility available	YES
Access to the premises	flat
Useful width of door/entrance gate	78.3 cm
Locker room size	width 242 cm and depth 163 cm
Presence of cot	NO
Coat rack height from the ground	Above 140 cm



### Beach

Type of beach	sand
Beach access	via concrete ramp 3 m long, > 100 cm wide slope 10 %
Walkway to reach the umbrellas	YES
Type of walkway	Wood with jute carpet on top
Width of the walkway	100 cm





<p>Removable Platform between the walkway and the umbrella station to facilitate the passage and parking wheelchair</p>	<p>NO</p>
<p>Amphibious beach chair available for helping people with reduced mobility to enjoy swimming (owned by the establishment or by association)</p>	<p>YES</p>

**Children's play area**

<p>Children's play area</p>	<p>inaccessible to children with reduced mobility due to sandy bottom</p>
-----------------------------	---





There are games for children with reduced mobility	NO

**Swimming pool**

The property has a swimming pool	NO
----------------------------------	----

**Medical practices/healthcare facilities**

Hospitals near the property	<p>For HEALTH EMERGENCIES 112 or 118 Azienda Ospedaliera Universitaria Pisana Emergency Room 050 992300 (it is active from 8.00 in the morning to 01.00 at night, after this time the Emergency Room can be contacted through the switchboard) Toll-free number 800.015877 Switchboard 050.992111 Santa Chiara Hospital Via Roma, 67 - Pisa (in the city center) Cisanello Hospital Via Paradisa, 2 - Cisanello - Pisa. On the eastern outskirts of Pisa</p>
Other healthcare facilities	tourist medical guard for the Pisan coast via Flavio Andò 5 in Marina di Pisa every



Project promoted by



**Regione Toscana**

---

	day from 10 to 13 and from 16 to 19, tel. 050 954681
--	--

**TESTED BY: [Handy Social Promotion Association Surpassable](#) in summer 2024**

---

Project carried out with the contribution of the



**Presidenza del  
Consiglio dei Ministri**  
Ministro per la disabilità