



Bathing establishment Fact Sheet

Name of bathing establishment	MARY
Address	Viale del Tirreno, 22
City	Tirrenia (PI)
Contacts	+39 050 33130 – infobagnomary@gmail.com
Website	Click or tap here to enter text.

TESTED BY: [Handy Social Promotion Association Surpassable](#) in summer 2024

Please note The following information refers to the date of verification shown at the bottom of each sheet. **The Association** is not responsible for any significant changes made by the property after the visit.

Summary

Bathing establishment Fact Sheet	1
Arrival at the property.....	2
Private/public parking.....	2
Pathway from the car park to the main entrance	3
Reception reception	3
Bar/restaurant	4
Internal pathways and common services	7
Internal pathways.....	7
Toilet and shower for guests with reduced mobility	7
Changing room	9
Beach.....	10
Children's play area	12
Swimming pool	13
Medical practices/healthcare facilities.....	13





Project carried out with the contribution of the





Arrival at the property



Private/public parking

Presence of private parking	YES
Type of private parking fund	asphalt
Presence of parking space reserved for people with disabilities	YES
Public parking nearby	YES to about 120 m.
Type of public parking floor	asphalt
	
	





Pathway from the car park to the main entrance

Pathway from the car park to the entrance	via ramp length 60m, width > 90 cm slope 5.2 %
There are indicators and tactile maps	NO
Useful width of door/entrance gate	Above 90 cm
	

Reception reception

Umbrella booking system	<input type="checkbox"/> Via the web <input checked="" type="checkbox"/> By phone <input checked="" type="checkbox"/> On-site
Presence of multilingual staff	YES
Presence of plant map with legend of services available	NO
Presence of visuo-tactile map	NO
Bulletin board/information panels with an average height of 130 cm in a well-lit area	NO





and a font size of at least 14 dpi with a contrast ratio greater than 4.5:1	
The staff followed a training course on welcoming people with different disabilities	NO

Bar/restaurant

Type of venue	Bar/restaurant /Self service
Access to the premises	Several entrances, one with a 7 cm step, the other with a ramp 2.26 m long, > 90 m wide, slope 10.5 %, internal ramp 1.53 m long, >90 cm wide, slope 8.7 %, from inside bar to terrace 4 cm step
Useful width of door/entrance gate	Above 90 cm
Bar bench	Above 100 cm . Banco self service, 72 e 86 cm
Types of tables	Various types between 4-legged and central support
Space under floor tables	Variable from 66 cm to 74 cm
Multilingual menu	YES
Large print menus	NO
Braille menu	NO
Table service for people with disabilities	YES
Availability of foods for celiacs	<input checked="" type="checkbox"/> bread <input type="checkbox"/> pasta <input checked="" type="checkbox"/> biscuits <input checked="" type="checkbox"/> ice cream <input checked="" type="checkbox"/> Pre-packaged foods



Project promoted by



Regione Toscana



Project carried out with the contribution of the




Presidenza del
Consiglio dei Ministri
Ministro per la disabilità

Project promoted by



Regione Toscana



Project carried out with the contribution of the



Presidenza del
Consiglio dei Ministri
Ministro per la disabilità



Internal pathways and common services

Internal pathways

Indicate whether the pathways connecting the entrance to the beach are flat or with ramps in addition to those already described

obstacle-free paths, to access the beach ramp 8.5 m long, >90 cm wide, slope 21.3 %, to reach walkway ramp 40 cm long, 90 cm wide, slope 14%





Toilet and shower for guests with reduced mobility

Number of accessible toilets for guests with reduced mobility	2 of which the first is a service area, the second on the beach
Access to the premises	Bathroom 1) flat. Bathroom 2) via access ramps to the beach
Usable width of the entrance door	Bathroom 1) 85.7 cm, Bathroom 2) 88 cm
Toilet height	Both 53 cm
Open front toilet seat	YES both
Support handles	on both sides
Flexible shower on the side of the toilet	YES both





Free space on the sides of the toilet	left above 90 cm first bath. Second bathroom 25.8 cm right 20.8 cm first bathroom Second bathroom above 90 Cm. frontal more than 90 cm. Second bathroom over 90 cm.
Electric doorbell/telephone	YES both
Washbasin with space underneath for wheelchair approach	First bathroom 62.2 cm. Second bathroom 64.5 cm
Height from the ground lower edge mirror	Missing in both bathrooms
Baby changing table	YES , outside the service area
	
	





<p>Accessible shower available for guests with reduced mobility</p>	<p>YES in common with the toilet rooms</p>
<p>Type of shower</p>	<p>open type</p>
<p>Floor-level shower</p>	<p>YES</p>
<p>Shower chair</p>	<p>wall-mounted folding only in the first bathroom</p>
<p>Support handle</p>	<p>YES</p>
<p>Presence of shower head or sliding rails</p>	<p>Hand shower</p>



Changing room

<p>Changing room accessible to guests with reduced mobility available</p>	<p>YES</p>
---	------------

Project carried out with the contribution of the





Access to the premises	Via the same ramps for access to the beach
Useful width of door/entrance gate	80 cm
Locker room size	Width 1.65 m and depth 1.84 m
Presence of cot	NO
Coat rack height from the ground	less than 140 cm and usable by people in a wheelchair
	

Beach

Type of beach	sand
Beach access	for access to the beach ramp 8.5 m long, >90 cm wide, slope 21.3 %, to reach walkway ramp 40 cm long, 90cm wide, slope 14%
Walkway to reach the umbrellas	YES
Type of walkway	wood
Width of the walkway	100 cm






<p>Removable Platform between the walkway and the umbrella station to facilitate the passage and parking wheelchair</p>	<p>YES</p>
<p>Amphibious beach chair available for helping people with reduced mobility to enjoy swimming (owned by the establishment or by association)</p>	<p>YES</p>





Children's play area

Children's play area	Accessible to children with reduced mobility
There are games for children with reduced mobility	YES. On-demand games can be moved to the grassy lawn
	





Swimming pool

The property has a swimming pool	NO
----------------------------------	----

Medical practices/healthcare facilities

Hospitals near the property	For HEALTH EMERGENCIES 112 or 118Azienda Ospedaliera Universitaria Pisana Emergency Room 050 992300 (it is active from 8.00 in the morning to 01.00 at night, after this time the Emergency Room can be contacted through the switchboard) Toll-free number 800.015877Switchboard 050.992111Santa Chiara Hospital Via Roma, 67 - Pisa (in the city center) Cisanello Hospital Via Paradisa, 2 - Cisanello - Pisa. On the eastern outskirts of Pisa
Other healthcare facilities	tourist medical guard for the Pisan coast via Flavio Andò 5 in Marina di Pisa every day from 10 to 13 and from 16 to 19, tel. 050 954681 .

TESTED BY: [Handy Social Promotion Association Surpassable](#) in summer 2024

