



Cultural Site Sheet

Cultural site name	Museum of the Territory of Populonia
Type of site	Museum
Address	Piazza della Cittadella 8
City	Piombino (LI)
Contacts	+39 0565226445
Website	http://www.parchivaldicornia.it/en
WCAG 2.1 compliant accessible website	NO

TESTED BY: [Handy Superabile Social Promotion Association](#) in summer 2024

Please note The following information refers to the date of verification shown at the bottom of each sheet. **The Association** is not responsible for any significant changes made by the property after the visit.

Summary

Cultural Site Sheet.....	1
Description.....	2
Arrival at the property.....	2
Private/public parking.....	2
Pathway from the car park to the entrance.....	3
Reception.....	4
Itineraries.....	5
Services.....	8
Additional elements.....	9
Toilets for guests with reduced mobility.....	10
Medical practices/healthcare facilities.....	12

Project carried out with the contribution of the





Description

The Archaeological Museum of the territory of Populonia exhibits finds from the ancient city of Populonia from the Paleolithic period to late antiquity with a special focus on the Etruscans and Romans. The museum preserves the ancient amphora of Baratti, a precious silver find found at sea.

General information

Opening and closing period	Tuesday to Saturday
Times	From 09.30 to 18.00
Ticket cost	Euro 8
Reductions	Euro 6. For more information on reductions or free admissions, see www.parchivaldicornia.it/info-e-servizi/orari-e-tariffe/
Online purchase	Yes
Pet access	Not detected

Arrival at the property

Private/public parking

Presence of private parking	NO
Public parking nearby	YES
Type of flooring in the public car park	asphalt
Presence of parking space reserved for people with disabilities	SI num 2.



Pathway from the car park to the entrance

The property can be reached from the car park	Obstacle-free
Distance from parking to entrance	100 meters
There are indicators and tactile maps	NO
There is an accessible entrance	YES main entrance
How to access the site	<input checked="" type="checkbox"/> via ramp One length 175 cm, width 200 cm, pendenza 8 %, <input type="checkbox"/>
Useful width of door/entrance gate	Above 90 cm
Type of door	with 2 doors that can be opened inwards
Type of handle	lever







Eventual notes	Presence of 0.5 cm step inside the entrance door
	
	

Reception

How to access	flat
Priority access for visitors with disabilities	YES
Orientation signs	<input checked="" type="checkbox"/> directional signs placed at 140/170 cm with contrasting colors
Type of information material	<input checked="" type="checkbox"/> guides in large print <input checked="" type="checkbox"/> Audio guides <input checked="" type="checkbox"/> tactile maps <input checked="" type="checkbox"/> QR code
A cloakroom accessible to visitors with motor disabilities is available	NO
Multilingual staff	YES



The staff followed a training course on welcoming people with different disabilities	YES
Presence of sign language interpreters	NO
Reception desk height	with a lowered bench part of less than 100 cm
The following aids are available for visitors with disabilities	<input checked="" type="checkbox"/> manual wheelchair <input checked="" type="checkbox"/> Crutches
	

Itineraries

Presence of maps	YES
Touch indicators and visual-touch maps	NO
Presence of didactic panels	YES
Audio guide	YES
Touch Models	YES
Multimedia workstations accessible from a seated position	YES with keypad placed 100 cm from the ground
Routes dedicated to children	YES



Project promoted by



Regione Toscana

	
	
	
Stopping points	YES
Route spread over several floors	YES no. 2 floors
Photo Plan	1

Project carried out with the contribution of the



Presidenza del
Consiglio dei Ministri
Ministro per la disabilità

Project promoted by



Regione Toscana



Photo Plan

2



Access to the starting point of the route





with ramp 490 cm long, over 90 cm wide, slope 9%,

Project carried out with the contribution of the



Presidenza del
Consiglio dei Ministri
Ministro per la disabilità



<p>How to access the rooms</p>	<p><input checked="" type="checkbox"/> by elevator Door width 89 cm, cabin width 140 cm, cabin depth 150cm, call button height 118 cm, highest button height keyboard 133, embossed/braille keys</p>
	
	
<p>Usable width of door/entrance gate/corridor</p>	<p>Above 90 cm</p>
<p>Room Identification</p>	<p>without identification sign</p>
<p>Bulletin board/information panels and captions</p>	<p><input checked="" type="checkbox"/> captions positioned at cm <u>80/120</u> from the ground</p> <p><input checked="" type="checkbox"/> Shadow-free fonts</p> <p><input checked="" type="checkbox"/> Well-contrasted font, better black on a white/cream background</p>

Services





Additional elements

Guided tours for groups	Yes
Guided tours for individuals	Yes
Activities for children and families	Yes
Guided tours with trained staff	<input checked="" type="checkbox"/> for visitors with reduced mobility
Accessible bookshop	<input checked="" type="checkbox"/> flat



Bar accessible from outside or from the ticket office. Route without obstacles. Door width greater than 90 cm





Toilets for guests with reduced mobility

Number of accessible toilets for guests with reduced mobility	2
Location of the toilet on floor 1	First floor
How to access the premises	<input checked="" type="checkbox"/> via ramp single length 165 cm, width 165cm, slope 10%, handrail left/right/both sides
Usable width of the entrance door	87 cm outside, 90 cm inside
Toilet height	50 cm
Toilet seat with open front tooth	YES
Support handles	on both sides
Flexible shower on the side of the toilet	NO
Free space on the sides of the toilet	left 30 cm right Above 90 cm frontal Above 90 cm
Electric doorbell/telephone	YES
Washbasin with space underneath for wheelchair approach	Above 70 cm
Height from the ground lower edge mirror	Missing mirror
Baby changing table	YES
Eventual notes	The changing table is located outside the toilet in a small room dedicated to mothers. (Breastfeeding station)



<p>Toilet location on floor 2</p>	<p>Second floor</p>
<p>How to access the premises</p>	<p><input checked="" type="checkbox"/> via ramp single length 165 cm, width 165 cm, slope 10%, handrail left/right/both sides</p>
<p>Usable width of the entrance door</p>	<p>80 cm outside, 90 cm inside</p>
<p>Toilet height</p>	<p>52 cm</p>
<p>Toilet seat with open front tooth</p>	<p>YES</p>
<p>Support handles</p>	<p>on both sides</p>
<p>Flexible shower on the side of the toilet</p>	<p>NO</p>
<p>Free space on the sides of the toilet</p>	<p>left 20 cm right Above 90 cm frontal Above 90 cm</p>
<p>Electric doorbell/telephone</p>	<p>YES</p>
<p>Washbasin with space underneath for</p>	<p>above 71 cm</p>





Height from the ground lower edge mirror	Missing mirror
Baby changing table	NO
	
	

Medical practices/healthcare facilities

Hospitals near the property	Villamarina Hospital via Forlanini 24 Piombino (LI) Phone +39 0565 67111
Other healthcare facilities	Asl Piombino via V.Veneto 43 telephone +39 0565 67610 Dialysis Center Phone +39 0565 67283 nefrologia.piombino@uslnordovest.toscana.it

TESTED BY: [Handy Superabile Social Promotion Association](#) in 2024

