



Cultural Site Sheet

Cultural site name	Palace of the Municipality of Piombino
Type of site	Town Hall
Address	Via Ferruccio Francesco 4
City	Piombino (LI)
Contacts	+39 0565 63111
Website	www.comune.piombino.li.it
WCAG 2.1 compliant accessible website	YES

TESTED BY: [Handy Superabile Social Promotion Association](#) in summer 2024

Please note The following information refers to the date of verification shown at the bottom of each sheet. **The Association** is not responsible for any significant changes made by the property after the visit.

Summary

Cultural Site Sheet.....	1
Description, general information	2
Arrival at the property.....	2
Private/public parking.....	2
Pathway from the car park to the entrance	3
Reception	5
Itineraries	6
Services	7
Additional elements.....	8
Toilets for guests with reduced mobility	8
Medical practices/healthcare facilities.....	9

Project carried out with the contribution of the





Description

The original nucleus dates back to 1200 when it was called Palazzo dei Priori, the current appearance dates back to 1444 and the clock tower dates back to 1598. Despite the various renovations, the building still retains a medieval appearance.


General information

Opening and closing period	Monday to Friday. Closed on holidays
Times	Every day from 9.00 a.m. to 1.00 p.m. Thursday also open in the afternoon from 16.00 to 19.00
Ticket cost	Free admission
Pet access	YES

Arrival at the property

Private/public parking

Presence of private parking	NO
Public parking nearby	YES
Type of flooring in the public car park	asphalt
Presence of parking space reserved for people with disabilities	SI number 3, 1 in Via G. Bruno and 1 in Piazza Bovio, 1 near the Duomo.





Pathway from the car park to the entrance

The property can be reached from the car park	Choose an item.
Distance from parking to entrance	From 100 to 200 meters
There are indicators and tactile maps	NO
There is an accessible entrance	YES main entrance
How to access the site	<input checked="" type="checkbox"/> on level ground and by elevator: Door width 90 cm, cabin width 100 cm, cabin depth 200 cm, call button height 110 cm, highest button height keyboard, 120 cm embossed/braille keys



Project promoted by



Regione Toscana




Useful width of door/entrance gate	Above 90 cm
Type of door	with 2 doors that can be opened inwards
Type of handle	Not present
	
	
	

Project carried out with the contribution of the



Presidenza del
Consiglio dei Ministri
Ministro per la disabilità




Reception

How to access	flat
Priority access for visitors with disabilities	YES
Orientation signs	<input checked="" type="checkbox"/> Signs identifying rooms and paths placed at 140/170 cm with contrasting colors
Type of information material	<input checked="" type="checkbox"/> Audio guides <input checked="" type="checkbox"/> QR code
A cloakroom accessible to visitors with motor disabilities is available	NO
Multilingual staff	YES
The staff followed a training course on welcoming people with different disabilities	NO



Presence of sign language interpreters	NO
Reception desk height	bench over 100 cm
	

Itineraries

Presence of maps	YES
Touch indicators and visual-touch maps	NO
Presence of didactic panels	NO
Audio guide	YES
Touch Models	NO
Multimedia workstations accessible from a seated position	NO
Routes dedicated to children	NO
Stopping points	YES
Route spread over several floors	YES
Access to the starting point of the route	flat
Eventual notes	



<p>How to access the rooms</p>	<ul style="list-style-type: none"> <input checked="" type="checkbox"/> flat <input checked="" type="checkbox"/> via ramp via 2 ramps, the first length 277 cm, width 140 cm, slope 10.5% handrail on both sides, the second length 310 cm, width 180 cm, slope 13% handrail on the left <input checked="" type="checkbox"/> by elevator Choose an item.
<p>Usable width of door/entrance gate/corridor</p>	<p>Above 90 cm</p>
<p>Room Identification</p>	<p>by means of a sign placed 140 cm from the ground</p>
<p>Eventual notes</p>	

Services






Additional elements

Guided tours for groups	NO
Guided tours for individuals	NO
Activities for children and families	NO
Eventual notes	The Town Hall is an institutional building in all respects.

Toilets for guests with reduced mobility

Number of accessible toilets for guests with reduced mobility	1
Location	Mezzanine ground floor
How to access the premises	<input type="checkbox"/> on level ground and via ramp length 277 cm, width 140 cm, slope 10.5 % handrail on both sides
Usable width of the entrance door	89 cm
Toilet height	50 cm
Toilet seat with open front tooth	YES
Support handles	on both sides
Flexible shower on the side of the toilet	NO
Free space on the sides of the toilet	left About 35 cm right Above 90 cm frontal Above 90 cm
Electric doorbell/telephone	NO
Washbasin with space underneath for wheelchair approach	Above 70 cm
Height from the ground lower edge mirror	Missing mirror
Baby changing table	NO
Eventual notes	



Medical practices/healthcare facilities

Hospitals near the property	Villamarina Hospital via Forlanini 24 Piombino (LI) Phone +39 0565 67111
Other healthcare facilities	Asl Piombino via V. Veneto 43 telephone +39 0565 67610 Dialysis Center Phone +39 0565 67283 nefrologia.piombino@uslnordovest.toscana.it

TESTED BY: [Handy Superabile Social Promotion Association](#) in 2024

