



## Bathing establishment Fact Sheet

Bathhouse name	CALAFURIA
Address	Viale Bernardini, 550
City	Lido di Camaiore (LU)
Contacts	Phone +39 0584619973- <a href="mailto:stefano-magnani@libero.it">stefano-magnani@libero.it</a>
Website	<a href="http://www.bagnocalafuria.it/">www.bagnocalafuria.it/</a>

**TESTED BY:** [Handy Superabile - Social Promotion Association](#) in summer 2023

**Please note** The following information refers to the verification date shown at the bottom of each card. **The Association** is not responsible for any significant changes made by the property after the visit.

### Summary

Bathing establishment Fact Sheet .....	1
Arrival at the facility .....	2
Private/public parking.....	2
Pathway from the parking lot to the main entrance .....	3
Reception.....	3
Bar/restaurant .....	4
Internal Pathways and common services.....	4
Internal Pathways .....	4
Toilet and shower accessible to guests with reduced mobility .....	5
Changing room .....	6
Beach.....	7
Children's play area .....	7
Swimming pool .....	8
Doctors' Offices/Healthcare Facilities .....	8


Project carried out with the contribution of the





## Arrival at the facility



### Private/public parking

Presence of private parking	YES
Type of private car park	gravel
Presence of parking space reserved for people with disabilities	YES n.2 seats
Public parking nearby	YES
Type of public car park	asphalt
	





### Pathway from the parking lot to the main entrance

Pathway from the car park to the entrance	flat on a gravel surface that can make it difficult for wheelchair users to move around
There are markers and tactile maps	NO
Usable door/entrance width	more than 90 cm
	

### Reception

Umbrella booking system	<input type="checkbox"/> Via web <input checked="" type="checkbox"/> By phone <input checked="" type="checkbox"/> On-site
Presence of multilingual staff	YES
Presence of plant plan with key to services available	NO
Presence of visuo-tactile map	NO
Bulletin board/information panels at an average height of 130 cm in a well-lit area	NO







and font size at least 14 dpi with a contrast ratio greater than 4.5:1	
The staff attended training courses on welcoming people with different disabilities	NO

**Bar/restaurant**

Type of venue	Restaurant Bar present but not active
---------------	---------------------------------------

**Internal Pathways and common services**



**Internal Pathways**

Indicate whether the pathways connecting the entrance to the beach are flat or with ramps in addition to those already described	Obstacle-free paths
	





**Toilet and shower accessible to guests with reduced mobility**


Number <b>of toilets</b> accessible/usable by guests with reduced mobility	1
Access to the premises	by ramp 280 cm long, > 90 cm wide slope 14.4%
Usable width of the entrance door	80 cm
Toilet height	48 cm
Open front toilet seat	NO
Support handles	on both sides
Flexible hand shower at the side of the toilet	NO
Free space on the sides of the toilet	left more than 90 cm right 30 cm frontal more than 90 cm
Electric doorbell/phone	YES
Washbasin with space underneath for wheelchair	Column not accessible
Height from the ground on the bottom edge of the mirror	Sufficient for use by wheelchair users
Baby changing table	NO
	
Accessible <b>shower</b> available for guests with reduced mobility	yes shared outdoors, cold water, no canopy







**Changing room**

Accessible changing room available for guests with reduced mobility	YES
Access to the premises	by ramp length 280 cm, width >90 cm, gradient 0.12 %
Usable door/entrance width	80 cm
Size of the dressing room	sufficient for wheelchair manoeuvring
Presence of a cot	NO
Coat rack height from the ground	over 140 cm





## Beach

Type of beach	sand
Access to the beach	Flat
Walkway to reach the umbrellas	YES
Type of walkway	PVC
Walkway width	100 cm
	
Removable Platform between the walkway and the umbrella station to facilitate the passage and parking wheelchair	NO
Amphibious beach chair available for helping people with reduced mobility to enjoy swimming (owned by the establishment or by association)	YES



## Children's play area

Children's play area	missing
There are games for children with reduced mobility	NO





## Swimming pool

The property has a swimming pool	YES
Access to the swimming pool	with a step
Useful width of the entrance gate	more than 90 cm
Access to the pool	with ladder
Bathing aids for guests with reduced mobility	amphibious chair
	

## Doctors' Offices/Healthcare Facilities

Hospitals near the facility	<b>Ospedale Versilia</b> SS 1, 335, 55049 Camaione LU Telephone: 0584 6051
Other Healthcare Facilities	<b>ASL Health District n. 12</b> Viareggio Via Sant'Elme, 30 Tel. 058483873 <b>Croce Verde</b> Viale Italoico, ang. via Risorgimento Tel. 058484013 Free First Aid for white codes Night <b>Medical Guard</b> Tel. 0584 83896 (h. 20-8) <b>Misericordia</b> Via P. I. da Carrara, 32 Tel. 0584752133/0584 752149



Project promoted by



**Regione Toscana**

---

	<p><b>Medical service "San Camillo" Nursing Home</b> Via P.I. da Carrara, 37 Tel. 0584 7391</p> <p><b>Dialysis service</b> c/o Croce Verde Viale Italice, ang. via Risorgimento Tel.058484013 affiliated with AUSL</p>
--	--

**TESTED BY: Handy Superabile Social Promotion Association in summer 2023**

---

Project carried out with the contribution of the



**Presidenza del  
Consiglio dei Ministri**  
Ministro per la disabilità