



## Bathing establishment Fact Sheet

Bathhouse name	Laura
Address	Via Arenile 7
City	Castiglione della Pescaia (Gr)
Contacts	Tel. + 39 3335830999
Website	Not detected

**TESTED BY:** [Handy Superabile - Social Promotion Association](#) in summer 2023

**Please note** The following information refers to the verification date shown at the bottom of each card. **The Association** is not responsible for any significant changes made by the property after the visit.

### Summary

Bathing establishment Fact Sheet .....	1
Arrival at the facility .....	2
Private/public parking.....	2
Pathway from the parking lot to the main entrance .....	2
Reception.....	3
Bar/restaurant .....	4
Internal Pathways and common services.....	5
Internal Pathways .....	5
Toilet and shower accessible to guests with reduced mobility .....	6
Changing room .....	7
Beach.....	8
Children's play area .....	10
Swimming pool .....	10
Doctors' Offices/Healthcare Facilities .....	10


Project carried out with the contribution of the





## Arrival at the facility

### Private/public parking

Presence of private parking	NO
Public parking nearby	YES
Presence of parking space reserved for people with disabilities	YES
Type of parking surface	ASPHALT
	

### Pathway from the parking lot to the main entrance

Pathway from the car park to the entrance	2 ramps: the first 10.5 m long, more than 90 cm wide, 17% slope; second length 17 cm, width more than 90 cm, gradient 7.6 %
There are markers and tactile maps	NO
Usable door/entrance width	more than 90 cm

Project promoted by



Regione Toscana



## Reception

Umbrella booking system	<input type="checkbox"/> Via web <input checked="" type="checkbox"/> By phone <input checked="" type="checkbox"/> On-site
Presence of multilingual staff	YES

Project carried out with the contribution of the



Presidenza del  
Consiglio dei Ministri  
Ministro per la disabilità



Presence of plant plan with key to services available	NO
Presence of visuo-tactile map	NO
Bulletin board/information panels at an average height of 130 cm in a well-lit area and font size at least 14 dpi with a contrast ratio greater than 4.5:1	NO
The staff attended training courses on welcoming people with different disabilities	NO

### Bar/restaurant

Type of venue	Bar/restaurant
Access to the premises	via ramp length 900 cm, width 135 cm, gradient 8 %
Usable door/entrance width	more than 90 cm
Bar counter	height less than 100 cm
Types of tables	with central support
Space underneath the tables from the floor	more than 70 cm
Multilingual menu	YES
Menus with large print fonts	NO
Braille menu	NO
Table service for people with disabilities	YES
Availability of gluten-free food	<input type="checkbox"/> bread <input type="checkbox"/> pasta <input type="checkbox"/> biscuits <input checked="" type="checkbox"/> ice cream <input checked="" type="checkbox"/> Pre-packaged foods



## Internal Pathways and common services

### Internal Pathways



Indicate whether the pathways connecting the entrance to the beach are flat or with ramps in addition to those already described

flat paths with a ramp 900 cm long and 135 cm wide with a gradient of 8 %







**Toilet and shower accessible to guests with reduced mobility**

Number <b>of toilets</b> accessible/usable by guests with reduced mobility	1
Access to the premises	Flat
Usable width of the entrance door	80 cm
Toilet height	50 cm
Open front toilet seat	YES
Support handles	on both sides of the toilet
Flexible hand shower at the side of the toilet	NO
Free space on the sides of the toilet	left more than 90 cm right cm 26 frontal more than 90 cm
Electric doorbell/phone	YES
Washbasin with space underneath for wheelchair	69 cm
Height from the ground on the bottom edge of the mirror	missing
Changing	NO
	
Accessible <b>shower</b> available for guests with reduced mobility	SI separated from the toilet room





Access to the shower room if separated from the toilet room	Flat
Useful width of the door/entrance gate if separated from the toilet room	more than 90 cm
Shower type	open-type
Floor-level shower	YES
Shower chair	missing
Grab bar	NO
Presence of shower head or ups and downs	fixed shower head
Electric doorbell/phone	NO
	

### Changing room


Accessible changing room available for guests with reduced mobility	YES
Access to the premises	Flat
Usable door/entrance width	more than 90 cm
Size of the dressing room	sufficient for wheelchair manoeuvring
Presence of a cot	NO
Coat rack height from the ground	Missing coat rack





Project promoted by



Regione Toscana



## Beach

Type of beach	sand
Access to the beach	via ramp length 900 cm, width 135 cm, gradient 8 %
Walkway to reach the umbrellas	YES
Type of walkway	PVC
Walkway width	100 cm
	

Project carried out with the contribution of the



Presidenza del  
Consiglio dei Ministri  
Ministro per la disabilità



<p>Removable Platform between the walkway and the umbrella station to facilitate the passage and parking wheelchair</p>	<p>YES</p>
<p>Amphibious beach chair available for helping people with reduced mobility to enjoy swimming (owned by the establishment or by association)</p>	<p>YES</p>



Project promoted by



Regione Toscana

### Children's play area

Children's play area	Not detected
----------------------	--------------

### Swimming pool

The property has a swimming pool	NO
----------------------------------	----

### Doctors' Offices/Healthcare Facilities

Hospitals near the facility	<b>Ospedale Misericordia</b> via Senese, 161 Grosseto at 25 km
Other Healthcare Facilities	<b>Presidio socio sanitario ASL</b> via Roma 1, Castiglione della Pescaia, tel 056443921 - 0564/43921 – 0564/483080 <b>Dialysis service on holiday</b> at Ospedale Misericordia Grosseto U.O. Nephrology and Dialysis Tel. 0564 485.218

TESTED BY: **Handy Superabile Social Promotion Association in summer 2023**

Project carried out with the contribution of the



Presidenza del  
Consiglio dei Ministri  
Ministro per la disabilità