



Bathing establishment Fact Sheet

Bathhouse name	GIGI
Address	Via delle Gorette
City	Marina di Cecina località Gorette
Contacts	+39 0586 620598
Website	www.facebook.com/bagnidagigi

TESTED BY: [Handy Superabile - Social Promotion Association](#) in summer 2023

Please note The following information refers to the verification date shown at the bottom of each card. **The Association** is not responsible for any significant changes made by the property after the visit.

Summary

Bathing establishment Fact Sheet.....	1
Arrival at the facility	2
Private/public parking.....	2
Pathway from the parking lot to the main entrance	2
Reception.....	3
Bar/restaurant	4
Internal Pathways and common services	5
Internal Pathways.....	5
Toilet and shower accessible to guests with reduced mobility.....	5
Changing room.....	8
Beach.....	9
Children's play area.....	10
Swimming pool.....	10
Doctors' Offices/Healthcare Facilities	10

Project carried out with the contribution of the





Arrival at the facility

Private/public parking

Presence of private parking	YES
Type of private car park	gravel
Presence of parking space reserved for people with disabilities	YES
Public parking nearby	YES
Type of public car park	asphalt



Pathway from the parking lot to the main entrance

Pathway from the car park to the entrance	with a step of 0.5 cm
There are markers and tactile maps	NO
Usable door/entrance width	more than 90 cm





Reception

Umbrella booking system	<input type="checkbox"/> Via web <input checked="" type="checkbox"/> By phone <input checked="" type="checkbox"/> On-site
Presence of multilingual staff	YES
Presence of plant plan with key to services available	NO
Presence of visuo-tactile map	NO
Bulletin board/information panels at an average height of 130 cm in a well-lit area and font size at least 14 dpi with a contrast ratio greater than 4.5:1	YES
The staff attended training courses on welcoming people with different disabilities	YES





Bar/restaurant

Type of venue	Bar/restaurant
Access to the premises	Flat
Usable door/entrance width	more than 90 cm
Bar counter	more than 100 cm
Types of tables	with central support
Space underneath the tables from the floor	greater than 70 cm for both types of table
Multilingual menu	YES
Menus with large print fonts	YES
Braille menu	NO
Table service for people with disabilities	YES
Availability of gluten-free food	<input type="checkbox"/> bread <input checked="" type="checkbox"/> pasta <input type="checkbox"/> biscuits <input checked="" type="checkbox"/> ice cream <input checked="" type="checkbox"/> Pre-packaged foods





Internal Pathways and common services

Internal Pathways

Indicate whether the pathways connecting the entrance to the beach are flat or with ramps in addition to those already described

Starting from the entrance near the disabled car park, the beach and all the premises of the establishment can be reached via a ramp with a length of 290 cm, a width of 157 cm, a gradient of 6.1%




Toilet and shower accessible to guests with reduced mobility

Number of toilets accessible/usable by guests with reduced mobility	2
Access to the premises	Flat en-suite bathroom; outdoor bathroom with 3 cm high step
Usable width of the entrance door	Both 80 cm
Toilet height	Both 50 cm
Open front toilet seat	NO, for both
Support handles	on both sides for both bathrooms





Flexible hand shower at the side of the toilet	NO, for en-suite bathrooms; YES for outdoor bathroom
Free space on the sides of the toilet in the en-suite bathroom	left 70 cm right 21 cm frontal more than 90 cm
Free space on the sides of the toilet in the outdoor bathroom	left more than 90 cm right 28 cm frontal more than 90 cm
Washbasin with space underneath for wheelchair	En-suite bathroom 69 cm; outdoor bathroom 67 cm
Height from the ground on the bottom edge of the mirror	100 cm for both bathrooms
Baby changing table	YES for en-suite bathrooms; NO, for outdoor bathrooms






	
Accessible shower available for guests with reduced mobility	YES in common with the outdoor toilet room
Useful width of the door/entrance gate if separated from the toilet room	80 cm
Shower type	open-type
Floor-level shower	YES
Shower chair	missing
Grab bar	YES
Presence of shower head or ups and downs	Ups and downs with the lowest point reachable by a seated person
Electric doorbell/phone	YES
Outdoor shower available accessible to guests with reduced mobility	Yes Outdoor with Canopy
Useful width of the door/entrance gate if separated from the toilet room	more than 90 cm
Shower type	open-type
Floor-level shower	YES
Shower chair	missing
Grab bar	YES
Presence of shower head or ups and downs	fixed shower head







Changing room

Accessible changing room available for guests with reduced mobility	YES
Access to the premises	with a step of 3 cm
Usable door/entrance width	80 cm
Size of the dressing room	147 cm wide and 195 cm deep
Presence of a cot	NO
Coat rack height from the ground	over 140 cm
Baby changing table	YES





Beach

Type of beach	sand
Access to the beach	via 2 ramps: the first length 290 cm, width 157 cm, gradient 6.1%; second length 9 cm, width 150 cm, gradient 6.3%
Walkway to reach the umbrellas	YES
Type of walkway	PVC and self-locking
Walkway width	100 cm
	
Removable Platform between the walkway and the umbrella station to facilitate the passage and parking wheelchair	YES
Amphibious beach chair available for helping people with reduced mobility to enjoy swimming (owned by the establishment or by association)	YES





Children's play area

Children's play area	missing
----------------------	---------

Swimming pool

The property has a swimming pool	NO
----------------------------------	----

Doctors' Offices/Healthcare Facilities

Hospitals near the facility	Cecina Hospital 6.8 km away; Via Montanara, Cecina
Other Healthcare Facilities	Tourist Medical Guard at 3.1 km; Viale Galliano, Marina di Cecina

TESTED BY: Handy Superabile Social Promotion Association in summer 2023

