



Bathing establishment Fact Sheet

Name of bathing establishment	ACALI
Address	Via Arenile,52
City	Forte dei Marmi (Lu)
Contacts	TEL. +39 0584874033 Email: info@bagnoacali.com
Website	http://www.bagnoacali.com/

TESTED BY: [Handy Superabile Social Promotion Association](#) in summer 2023

Please note The following information refers to the verification date shown at the bottom of each sheet. The Association is not responsible for any significant changes made to the property after the visit.

Summary

Bathing establishment Fact Sheet	1
Arrival at the facility	2
Private/public parking.....	2
Pathway from the parking lot to the main entrance	3
Reception welcome.....	4
Bar/restaurant	4
Internal Pathways and common services.....	6
Internal Pathways	6
Toilet and shower accessible to guests with reduced mobility	6
Changing room	7
Beach.....	8
Children's play area	10
Pool.....	10
Medical practices/health facilities.....	10

Project carried out with the contribution of





Arrival at the facility

Private/public parking


Presence of private parking	YES
Fund type of private parking	gravel
Presence of parking space reserved for people with disabilities	YES
Public parking nearby	YES
Fund type of public car park	asphalt





Pathway from the parking lot to the main entrance

Pathway from the parking lot to the entrance	flat on a gravel surface which can make movement difficult for people in wheelchairs
There are indicators and tactile maps	NO
Useful width of door/entrance passage	greater than 90 cm





Reception welcome

Umbrella booking system	<input type="checkbox"/> Via the web <input checked="" type="checkbox"/> Via telephone <input checked="" type="checkbox"/> On site
Presence of multilingual staff	YES
Presence of plant plan with legend of services available	NO
Presence of visuo-tactile map	NO
Noticeboard/information panel sat an average height of 130 cm in a well-lit area and a character size of at least 14 dpi with a contrast ratio greater than 4.5:1	NO
The staff has undergone training on welcoming people with various disabilities	NO

Bar/restaurant

Type of venue	Bar/restaurant
Access to the venue	Via a ramp 217 cm long, width > 90 cm, slope 9% to overcome a difference in height of 18 cm or via a ramp 28 cm long, width > 90 cm to overcome a small step of 5 cm.
Useful width of door/entrance passage	greater than 90 cm
Bar counter	103cm
Type of tables	With 4 legs and central support
Space under the floor tables	70cm
Multilingual menu	not detected





Menu with large print characters	NO
Braille menu	NO
Table service for people with disabilities	YES
Availability of food for celiacs	<input type="checkbox"/> bread <input type="checkbox"/> pasta <input type="checkbox"/> cookies <input type="checkbox"/> ice creams <input type="checkbox"/> pre-packaged foods





Internal Pathways and common services

Internal Pathways

Indicate whether the pathways connecting the entrance to the beach are flat or with ramps in addition to those already described	obstacle-free routes
--	----------------------

Toilet and shower accessible to guests with reduced mobility

Number of toilets accessible/usable by guests with reduced mobility	1
Access to the venue	Via a ramp 217 cm long, width > 90 cm, slope 9% to overcome a difference in height of 18 cm or via a short ramp 28 cm long, width > 90 cm to overcome a small step of 5 cm.
Useful width of entrance door	87 cm
Toilet height	50cm
Open front toilet seat	YES
Support handles	on both sides
Flexible shower next to the toilet	NO
Free space on the sides of the toilet	to the left greater than 90 cm To the right 25cm Front greater than 90 cm
Electric bell/telephone	YES with push button
Washbasin with space underneath for a wheelchair	65cm
Height from the ground to the lower edge of the mirror	sufficient for use by a person in a wheelchair
Baby changing table	not detected






<p>Shower accessible to guests with reduced mobility available</p>	<p>YES in common with the toilet room</p>
<p>Shower type</p>	<p>open type</p>
<p>Floor-level shower</p>	<p>YES</p>
<p>Shower chair</p>	<p>missing</p>
<p>Support handle</p>	<p>YES</p>
<p>Presence of shower head or latch</p>	<p>latch with lowest point height 122 cm</p>
<p>Electric bell/telephone</p>	<p>NO</p>

Changing room





Changing room accessible to guests with reduced mobility available	YES
Access to the venue	via short ramp 54 cm long, width > 90 cm, slope 18%.
Useful width of door/entrance passage	82cm
Dimensions of the changing room	sufficient for guest maneuvering in a wheelchair
Presence of cot	NO
Coat stand height from the floor	less than 140 cm and accessible to people in wheelchairs
	

Beach

Type of beach	sand
Access to the beach	via ramp: length 405 cm, slope 12%
Walkway to reach the umbrellas	YES
Type of walkway	wood
Walkway width	90cm





<p>Removable platform between walkway and the umbrella station to facilitate the passage and parking wheelchair</p>	<p>YES</p>
<p>Amphibious beach chair available for helping people with reduced mobility to enjoy swimming (owned by the establishment or by association)</p>	<p>YES</p>





Children's play area

Children's play area	missing
----------------------	---------

Pool

The property has a swimming pool	NO
----------------------------------	----

Medical practices/health facilities

Hospitals near the facility	Versilia Hospital SS 1, 335, 55049 Camaiole LU Telephone: 0584 6051
Other healthcare facilities	ASL Health District No. 12 Viareggio Via Sant'Elme, 30 Tel. 058483873 Green Cross Viale Italico, corner. via Risorgimento Tel. 058484013 Free first aid for white codes Night medical guard Tel. 0584 83896 (8pm-8am) Mercy Via PI da Carrara, 32 Tel. 0584752133/0584 752149 Medical service "San Camillo" nursing home Via PI da Carrara, 37 Tel. 0584 7391 Dialysis service Croce Verde Viale Italico, corner. via Risorgimento Tel.058484013 affiliated with AUSL

TESTED BY: Handy Superabile Social Promotion Association in summer 2023

