



Bathing establishment Fact sheet

Name of bathing establishment	LA PERLA
Address	Via Arenile,36
City	Forte dei Marmi (Lu)
Contacts	Telephone +39 0584 82204
Website	https://www.facebook.com/bagnolaperlafortedeimarmi/?locale=it_IT

TESTED BY: [Handy Superabile Social Promotion Association](#) in summer 2023

Please note The following information refers to the verification date shown at the bottom of each sheet. The Association is not responsible for any significant changes made to the property after the visit.

Summary

Bathing establishments Fact sheet	1
Arrival at the facility	2
Private/public parking.....	2
Path from the parking lot to the main entrance	3
Reception welcome.....	4
Bar/restaurant	4
Internal pathways and common services	5
Internal pathways.....	5
Toilet and shower accessible to guests with reduced mobility	6
Changing room	8
Beach.....	9
Children's play area	11
Pool.....	11
Medical practices/health facilities.....	11

Project carried out with the contribution of





Arrival at the facility

Private/public parking

Presence of private parking	YES
Fund type of private parking	gravel
Presence of parking space reserved for people with disabilities	YES
Public parking nearby	YES
Fund type of public car park	asphalt
	





Pathway from the parking lot to the main entrance

Pathway from the parking lot to the entrance	flat on a gravel surface which can make movement difficult for people in wheelchairs
There are indicators and tactile maps	NO
Useful width of door/entrance passage	greater than 90 cm





Reception welcome

Umbrella booking system	<input type="checkbox"/> Via the web <input checked="" type="checkbox"/> Via telephone <input checked="" type="checkbox"/> On site
Presence of multilingual staff	not detected
Presence of plant plan with legend of services available	NO
Presence of visuo-tactile map	NO
Noticeboard/information panel sat an average height of 130 cm in a well-lit area and a character size of at least 14 dpi with a contrast ratio greater than 4.5:1	NO
The staff has undergone training on welcoming people with various disabilities	NO

Bar/restaurant

Type of venue	Bar/restaurant
Access to the venue	flat
Useful width of door/entrance passage	greater than 90 cm
Bar counter	116 cm
Type of tables	with 4 legged
Space under the floor tables	65 cm
Multilingual menu	not detected
Menu with large print characters	NO
Braille menu	NO
Table service for people with disabilities	YES





<p>Availability of food for celiacs</p>	<p><input type="checkbox"/>bread <input type="checkbox"/>pasta <input type="checkbox"/>cookies <input type="checkbox"/>ice creams <input type="checkbox"/>pre-packaged foods</p>
	
	

Internal pathways and common services



Internal pathways

<p>Indicate whether the pathways connecting the entrance to the beach are flat or with ramps in addition to those already described</p>	<p>obstacle-free pathways</p>
---	-------------------------------







Toilet and shower accessible to guests with reduced mobility

Number of toilets accessible/usable by guests with reduced mobility	1
Access to the venue	flat
Useful width of entrance door	85cm
Toilet height	55cm
Open front toilet seat	NO
Support handles	on both sides
Flexible shower next to the toilet	NO
Free space on the sides of the toilet	to the left greater than 90 cm To the right 20cm Front greater than 90 cm
Electric bell/telephone	YES
Washbasin with space underneath for a wheelchair	70cm
Height from the ground to the lower edge of the mirror	not sufficient for use by people in a wheelchair
Baby changing table	not detected
	





Shower accessible to guests with reduced mobility available	yes outdoors without a roof
Access to the shower room if separated from the toilet room	flat
Useful width of entrance door/gap if separated from the toilet room	68cm
Shower type	open type
Floor-level shower	YES
Shower chair	missing
Support handle	missing
Presence of shower head or latch	fixed shower head with flexible hand shower 118 cm from the ground
Electric bell/telephone	NO
	





	<p>Shower box with fixed shower head and flexible hand shower 118 cm from the ground</p>
--	--

Changing room

<p>Changing room accessible to guests with reduced mobility available</p>	<p>YES</p>
<p>Access to the venue</p>	<p>flat</p>
<p>Useful width of door/entrance passage</p>	<p>83 cm</p>
<p>Dimensions of the changing room</p>	<p>sufficient for guest maneuvering in a wheelchair</p>
<p>Presence of cot</p>	<p>NO</p>
<p>Coat stand height from the floor</p>	<p>greater than 140 cm and not accessible to people in wheelchairs</p>





Beach


Type of beach	sand
Access to the beach	flat
Walkway to reach the umbrellas	YES
Type of walkway	cement
Walkway width	100cm





	
<p>Removable Platform between the walkway and the umbrella station to facilitate the passage and parking wheelchair</p>	<p>YES</p>
<p>Amphibious beach chair available for helping people with reduced mobility to enjoy swimming (owned by the establishment or by association)</p>	<p>YES</p>
	





Children's play area

Children's play area	accessible to children with reduced mobility
There are games for children with reduced mobility	NO

Pool

The property has a swimming pool	NO
----------------------------------	----

Medical practices/health facilities

Hospitals near the facility	Versilia Hospital SS 1, 335, 55049 Camaione LU Telephone: 0584 6051
Other healthcare facilities	ASL Health District No. 12 Viareggio Via Sant'Elme, 30 Tel. 058483873



Project promoted by



Regione Toscana

	<p>Green Cross Viale Italice, corner the via Risorgimento Tel. 058484013 Free first aid for white codes Night medical guard Tel. 0584 83896 (8pm-8am)</p> <p>Mercy Via PI da Carrara, 32 Tel. 0584752133/0584 752149</p> <p>Medical service “San Camillo” nursing home Via PI da Carrara, 37 Tel. 0584 7391</p> <p>Dialysis service Green Cross Viale Italice, corner the via Risorgimento Tel.058484013 affiliated with AUSL</p>
--	--

TESTED BY: Handy Superabile - Social Promotion Association _ in summer 2023

Project carried out with the contribution of



Presidenza del
Consiglio dei Ministri
Ministro per la disabilità