



## Bathing establishment Fact Sheet

Name of bathing establishment	MILANO
Address	Via Arenile,50
City	Forte dei Marmi (Lu)
Contacts	Telephone +390584 81872
Website	<a href="https://www.bagnomilano.org/en/default.asp">https://www.bagnomilano.org/en/default.asp</a>

**TESTED BY:** [Handy Superabile Social Promotion Association in summer 2023](#)

**Please note** The following information refers to the verification date shown at the bottom of each sheet. The Association is not responsible for any significant changes made to the property after the visit.

### Summary

Bathing establishment Fact Sheet .....	1
Arrival at the facility .....	2
Private/public parking.....	2
Pathway from the parking lot to the main entrance .....	2
Reception welcome.....	3
Bar/restaurant .....	4
Internal pathways and common services .....	5
Internal pathways.....	5
Toilet and shower accessible to guests with reduced mobility .....	6
Changing room .....	8
Beach.....	8
Children's play area .....	9
Pool.....	10
Medical practices/health facilities.....	10

Project carried out with the contribution of





## Arrival at the facility

### Private/public parking

Presence of private parking	YES
Fund type of private parking	gravel
Presence of parking space reserved for people with disabilities	NO
Public parking nearby	YES
Fund type of public car park	asphalt
	

### Pathway from the parking lot to the main entrance

Pathway from the parking lot to the entrance	flat on a gravel surface which can make movement difficult for people in wheelchairs
There are indicators and tactile maps	NO
Useful width of door/entrance passage	accessible via 1 2cm step and ramp: length 80cm, width cm, slope 6






### Reception welcome

Umbrella booking system	<input type="checkbox"/> Via the web <input checked="" type="checkbox"/> Via telephone <input checked="" type="checkbox"/> On site
Presence of multilingual staff	not detected
Presence of plant plan with legend of services available	NO
Presence of visuo-tactile map	NO
Noticeboard/information panel sat an average height of 130 cm in a well-lit area and a character size of at least 14 dpi with a contrast ratio greater than 4.5:1	NO
The staff has undergone training on welcoming people with various disabilities	NO





**Bar/restaurant**

Type of venue	Bar/restaurant
Access to the venue	flat
Useful width of door/entrance passage	>90 cm
Bar counter	103cm
Type of tables	with 4 legged
Space under the floor tables	65<74 cm
Multilingual menu	not detected
Menu with large print characters	NO
Braille menu	NO
Table service for people with disabilities	YES
Availability of food for celiacs	<input type="checkbox"/> bread <input type="checkbox"/> pasta <input type="checkbox"/> cookies <input type="checkbox"/> ice creams <input type="checkbox"/> pre-packaged foods





**Internal pathways and common services**

**Internal pathways**

Indicate whether the pathways connecting the entrance to the beach are flat or with ramps in addition to those already described

obstacle-free pathways





**Toilet and shower accessible to guests with reduced mobility**

Number of toilets accessible/usable by guests with reduced mobility	1
Access to the venue	with a step of 2 cm
Useful width of entrance door	88cm
Toilet height	52cm
Open front toilet seat	YES
Support handles	to the right of the toilet
Flexible shower next to the toilet	NO
Free space on the sides of the toilet	to the left 23cm To the right >90 cm front >90 cm
Electric bell/telephone	YES
Washbasin with space underneath for a wheelchair	65<83 cm
Height from the ground to the lower edge of the mirror	not sufficient for use by people in a wheelchair
Baby changing table	not detected





	
<p>Shower accessible to guests with reduced mobility available</p>	<p>YES separated from the toilet room</p>
<p>Access to the shower room if separated from the toilet room</p>	<p>Flat but with limited space and button at a height that cannot be reached by a wheelchair user but there are 2 outdoor showers at floor level with accessible tap</p>
	






### Changing room

Changing room accessible to guests with reduced mobility available	YES
Access to the venue	flat
Useful width of door/entrance passage	90cm
Dimensions of the changing room	not detected
Presence of cot	NO
Coat stand height from the floor	greater than 140 cm and not accessible to people in wheelchairs

### Beach

Type of beach	sand
Access to the beach	reachable via a slight downhill difference in altitude and a 3% slope and a small 2 cm step
Walkway to reach the umbrellas	YES
Type of walkway	PVC
Walkway width	90cm





<p>Removable Platform between the walkway and the umbrella station to facilitate the passage and parking wheelchair</p>	<p>YES</p>
<p>Amphibious beach chair available for helping people with reduced mobility to enjoy swimming (owned by the establishment or by association)</p>	<p>can request one of the four JOB chairs supplied to the Forte dei Marmi beach association</p>
	

**Children's play area**

<p>Children's play area</p>	<p>inaccessible to children with reduced mobility due to the sandy bottom There is a ping pong table on the floor</p>
<p>There are games for children with reduced mobility</p>	<p>NO</p>





	<p>ping pong table on a paved surface</p>
--	---

**Pool**

<p>The property has a swimming pool</p>	<p>NO</p>
<p>Bathing aids for guests with reduced mobility</p>	<p>amphibious chair</p>

**Medical practices/health facilities**

<p>Hospitals near the facility</p>	<p><b>Versilia Hospital SS 1, 335, 55049 Camaione LU Telephone: 0584 6051</b></p>
<p>Other healthcare facilities</p>	<p><b>ASL Health District No. 12</b> Viareggio Via Sant'Elme, 30 Tel. 058483873 <b>Green Cross</b> Viale Italico, corner the via Risorgimento Tel. 058484013 Free first aid for white codes <b>Night medical guard</b> Tel. 0584 83896 (8pm-8am) <b>Mercy</b> Via PI da Carrara, 32 Tel. 0584752133/0584 752149</p>



Project promoted by



**Regione Toscana**

---

	<p><b>Medical service “San Camillo” nursing home</b> Via PI da Carrara, 37 Tel. 0584 7391</p> <p><b>Dialysis service</b> Green Cross Viale Italiceo, corner the via Risorgimento Tel.058484013 affiliated with AUSL</p>
--	---

TESTED BY: Handy Superabile - Social Promotion Association - in summer 2023

---

Project carried out with the contribution of



**Presidenza del  
Consiglio dei Ministri**  
Ministro per la disabilità