



## Bathing establishment Fact Sheet

Bathhouse name	LE PALME
Address	Viale Sergio Bernardini n. 622
City	Lido di Camaiore (Lu)
Contacts	+39 329 1108734
Website	Not detected

**TESTED BY:** [Handy Superabile - Social Promotion Association](#) in summer 2023

**Please note** The following information refers to the verification date shown at the bottom of each card. **The Association** is not responsible for any significant changes made by the property after the visit.

### Summary

Bathing establishment Fact Sheet .....	1
Arrival at the facility .....	2
Private/public parking.....	2
Pathway from the parking lot to the main entrance .....	3
Reception.....	3
Bar/restaurant .....	4
Internal Pathways and common services.....	5
Internal Pathways .....	5
Toilet and shower accessible to guests with reduced mobility .....	5
Changing room .....	7
Beach.....	7
Children's play area .....	8
Swimming pool .....	9
Doctors' Offices/Healthcare Facilities .....	9

Project carried out with the contribution of the





### Arrival at the facility



#### Private/public parking

Presence of private parking	YES
Type of private car park	gravel
Presence of parking space reserved for people with disabilities	NO
Public parking nearby	YES
Type of public car park	asphalt





### Pathway from the parking lot to the main entrance

Pathway from the car park to the entrance	flat on a gravel surface that can make it difficult for wheelchair users to move around
There are markers and tactile maps	NO
Usable door/entrance width	more than 90 cm
	

### Reception

Umbrella booking system	<input type="checkbox"/> Via web <input checked="" type="checkbox"/> By phone <input checked="" type="checkbox"/> On-site
Presence of multilingual staff	YES
Presence of plant plan with key to services available	YES
Presence of visuo-tactile map	NO





Bulletin board/information panels at an average height of 130 cm in a well-lit area and font size at least 14 dpi with a contrast ratio greater than 4.5:1	NO
The staff attended training courses on welcoming people with different disabilities	NO

### Bar/restaurant

Type of venue	Snack bar
Access to the premises	Flat
Usable door/entrance width	above 90
Bar counter	more than 100 cm
Types of tables	4-legged
Space underneath the tables from the floor	65 cm
Multilingual menu	NO
Menus with large print fonts	NO
Braille menu	NO
Table service for people with disabilities	YES
Availability of gluten-free food	<input type="checkbox"/> bread <input type="checkbox"/> pasta <input checked="" type="checkbox"/> biscuits <input checked="" type="checkbox"/> ice cream <input type="checkbox"/> Pre-packaged foods





### Internal Pathways and common services

#### Internal Pathways

Indicate whether the pathways connecting the entrance to the beach are flat or with ramps in addition to those already described	Obstacle-free paths
--	---------------------

#### Toilet and shower accessible to guests with reduced mobility

Number <b>of toilets</b> accessible/usable by guests with reduced mobility	1
Access to the premises	Flat
Usable width of the entrance door	more than 90 cm
Toilet height	46 cm
Open front toilet seat	YES
Support handles	on both sides





Flexible hand shower at the side of the toilet	YES
Free space on the sides of the toilet	left more than 90 cm right 24 Cm frontal more than 90 cm
Electric doorbell/phone	YES
Washbasin with space underneath for wheelchair	66 cm
Height from the ground on the bottom edge of the mirror	Missing mirror
Baby changing table	NO
	
Accessible <b>shower</b> available for guests with reduced mobility	YES shared with the toilet room and an external one with a 2 cm step
Access to the shower room if separated from the toilet room	Flat
Useful width of the door/entrance gate if separated from the toilet room	more than 90 cm
Shower type	open-type
Floor-level shower	YES
Shower chair	missing
Grab bar	YES
Presence of shower head or ups and downs	Sliding rails with a lowest point height of more than 100 cm





Electric doorbell/phone	YES
	

### Changing room

Accessible changing room available for guests with reduced mobility	YES
Access to the premises	Flat
Usable door/entrance width	80 cm
Size of the dressing room	width 230 cm and depth 208 cm
Presence of a cot	NO
Coat rack height from the ground	Adjustable above 100 cm

### Beach

Type of beach	sand
Access to the beach	by ramp length 96 cm, width 91 cm, slope 6 %
Walkway to reach the umbrellas	YES
Type of walkway	PVC
Walkway width	91 cm






<p>Removable Platform between the walkway and the umbrella station to facilitate the passage and parking wheelchair</p>	<p>YES</p>
<p>Amphibious beach chair available for helping people with reduced mobility to enjoy swimming (owned by the establishment or by association)</p>	<p>YES</p>

### Children's play area

<p>Children's play area</p>	<p>Accessible to children with reduced mobility</p>
<p>There are games for children with reduced mobility</p>	<p>NO</p>





### Swimming pool

The property has a swimming pool	NO
----------------------------------	----

### Doctors' Offices/Healthcare Facilities

Hospitals near the facility	Ospedale Versilia SS 1, 335, 55049 Camaiole LU Telephone: 0584 6051
Other Healthcare Facilities	<p><b>ASL Health District n. 12</b> Viareggio Via Sant'Elme, 30 Tel. 058483873</p> <p><b>Croce Verde</b> Viale Italice, angolo via Risorgimento Tel. 058484013 Free First Aid for white codes <b>Night medical service</b> Tel. 0584 83896 (h. 20-8)</p> <p><b>Misericordia</b> Via P. I. da Carrara, 32 Tel. 0584752133/0584 752149</p> <p><b>Medical service "San Camillo" Nursing Home</b> Via P.I. da Carrara, 37 Tel. 0584 7391</p> <p><b>Dialysis service</b> at Croce Verde Viale Italice, angolo via</p>



Project promoted by



**Regione Toscana**

---

	Risorgimento Tel.058484013 affiliated with AUSL
--	---

**TESTED BY: Handy Superabile Social Promotion Association in summer 2023**

---

Project carried out with the contribution of the



**Presidenza del  
Consiglio dei Ministri**  
Ministro per la disabilità