



Bathing establishment Fact Sheet

| | |
|----------------|-----------------------|
| Bathhouse name | Milano |
| Address | Via S: Bernardini 714 |
| City | Lido di Camaiore (LU) |
| Contacts | +39 333 4937104 |
| Website | Not detected |

TESTED BY: [Handy Superabile - Social Promotion Association](#) in summer 2023

Please note The following information refers to the verification date shown at the bottom of each card. **The Association** is not responsible for any significant changes made by the property after the visit.

Summary

| | |
|--|----|
| Bathing establishment Fact Sheet | 1 |
| Arrival at the facility | 2 |
| Private/public parking..... | 2 |
| Pathway from the parking lot to the main entrance | 3 |
| Reception..... | 3 |
| Bar/restaurant | 4 |
| Internal Pathways and common services..... | 4 |
| Internal Pathways | 4 |
| Toilet and shower accessible to guests with reduced mobility | 5 |
| Changing room | 7 |
| Beach..... | 8 |
| Children's play area | 9 |
| Swimming pool | 10 |
| Doctors' Offices/Healthcare Facilities | 10 |

Project carried out with the contribution of the





Project promoted by



Regione Toscana

Arrival at the facility

Private/public parking

| | |
|--|---|
| Presence of private parking | YES |
| Presence of parking space reserved for people with disabilities | YES |
| Type of parking surface | GRAVEL |
| Public parking nearby | YES |
|  |  |



Project carried out with the contribution of the



Presidenza del
Consiglio dei Ministri
Ministro per la disabilità



Pathway from the parking lot to the main entrance

| | |
|--|--|
| Pathway from the car park to the entrance | by ramp length 233 cm, width 82 cm, slope 8.2% continuing the width of the ramp becomes cm. 69 |
| There are markers and tactile maps | NO |
| Usable door/entrance width | more than 90 cm |
|  |  |

Reception

| | |
|---|---|
| Umbrella booking system | <input type="checkbox"/> Via web <input checked="" type="checkbox"/> By phone <input checked="" type="checkbox"/> On-site |
| Presence of multilingual staff | YES |
| Presence of plant plan with key to services available | NO |





| | |
|--|----|
| Presence of visuo-tactile map | NO |
| Bulletin board/information panels at an average height of 130 cm in a well-lit area and font size at least 14 dpi with a contrast ratio greater than 4.5:1 | NO |
| The staff attended training courses on welcoming people with different disabilities | NO |

Bar/restaurant

| | |
|---------------|---------|
| Type of venue | missing |
|---------------|---------|

Internal Pathways and common services

Internal Pathways

| | |
|--|--|
| Indicate whether the pathways connecting the entrance to the beach are flat or with ramps in addition to those already described | flat paths with a ramp 233 cm long and 82 cm wide with a slope of 8.2% |
|--|--|







Toilet and shower accessible to guests with reduced mobility

| | |
|--|--|
| Number of toilets accessible/usable by guests with reduced mobility | 1 |
| Access to the premises | through 2 ramps: the first length 204 cm, width 100 cm, slope 3.6%; second length 763 cm, width 95 cm, slope 5.8 % |
| Usable width of the entrance door | cm 77 |
| Toilet height | cm 47 |
| Open front toilet seat | YES |
| Support handles | to the right of the toilet |
| Flexible hand shower at the side of the toilet | NO |
| Free space on the sides of the toilet | left cm 20 right more than 90 cm frontal cm 64 |
| Electric doorbell/phone | YES |
| Washbasin with space underneath for wheelchair | cm 78 |





| | |
|---|--|
| Height from the ground on the bottom edge of the mirror | cm 111 |
| Baby changing table | NO |
|  |  |
| Accessible shower available for guests with reduced mobility | YES in common with the toilet room |
| Shower type | open-type |
| Floor-level shower | YES |
| Shower chair | missing |
| Grab bar | YES |
| Presence of shower head or ups and downs | Fixed shower head at cm 204 |
| Electric doorbell/phone | YES |





Changing room

| | |
|---|--|
| Accessible changing room available for guests with reduced mobility | YES |
| Access to the premises | through 2 ramps: the first one is 204 cm long, 100 cm wide and 3.6% slope; second length cm, 763 cm wide, 95 cm wide, slope 5.8% |
| Usable door/entrance width | cm 83 |
| Size of the dressing room | width 148 cm and depth 180 cm |
| Presence of a cot | NO |
| Coat rack height from the ground | cm 165 |





Project promoted by



Regione Toscana



Beach

| | |
|---|--|
| Type of beach | sand |
| Access to the beach | Flat |
| Walkway to reach the umbrellas | YES |
| Type of walkway | concrete |
| Walkway width | 100 cm |
|  |  |

Project carried out with the contribution of the



Presidenza del
Consiglio dei Ministri
Ministro per la disabilità



| | |
|--|---|
| Removable Platform between the walkway and the umbrella station to facilitate the passage and parking wheelchair | YES |
| Amphibious beach chair available for helping people with reduced mobility to enjoy swimming (owned by the establishment or by association) | YES |
|  |  |

Children's play area

| | |
|--|--|
| Children's play area | inaccessible to children with reduced mobility due to sandy bottom |
| There are games for children with reduced mobility | NO |





Swimming pool

| | |
|----------------------------------|----|
| The property has a swimming pool | NO |
|----------------------------------|----|

Doctors' Offices/Healthcare Facilities

| | |
|-----------------------------|--|
| Hospitals near the facility | Ospedale Versilia ss1, 335 Camaiore tel 0584/6051 |
| Other Healthcare Facilities | <p>Emergency medical service Camaiore tel. 0584/616775 Distretto Sanitario ASL N. 12 Viareggio Via Sant'Elme, 30 Tel. 058483873</p> <p>Croce Verde Viale Italice, angolo via Risorgimento Tel. 058484013 Free First Aid for white codes Night medical guard Tel. 0584 83896 (h. 20-8)</p> |



Project promoted by



Regione Toscana

| | |
|--|--|
| | <p>Misericordia Via P. I. da Carrara, 32 Tel. 0584752133/0584 752149</p> <p>Medical service "San Camillo" Nursing Home Via P.I. da Carrara, 37 Tel. 0584 7391</p> <p>Dialysis service c/o Croce Verde Viale Italiceo, corner of Via Risorgimento Tel.058484013 affiliated with AUSL</p> |
|--|--|

TESTED BY: Handy Superabile Social Promotion Association in summer 2023

Project carried out with the contribution of the



Presidenza del
Consiglio dei Ministri
Ministro per la disabilità