



## Bathing establishment Fact Sheet

Bathhouse name	Riviera
Address	Viale Europa 189
City	Lido di Camaiore (LU)
Contacts	Tel. 0584 617217 mail: <a href="mailto:info@bagnoriviera.com">info@bagnoriviera.com</a>
Website	<a href="http://www.bagnoriviera.com/inglese">www.bagnoriviera.com/inglese</a>

**TESTED BY:** [Handy Superabile - Social Promotion Association](#) in summer 2023

**Please note** The following information refers to the verification date shown at the bottom of each card. **The Association** is not responsible for any significant changes made by the property after the visit.

### Summary

Bathing establishment Fact Sheet .....	1
Arrival at the facility .....	2
Private/public parking.....	2
Pathway from the parking lot to the main entrance .....	2
Reception.....	3
Bar/restaurant .....	4
Internal Pathways and common services.....	5
Internal Pathways .....	5
Toilet and shower accessible to guests with reduced mobility .....	5
Changing room .....	7
Beach.....	8
Children's play area .....	9
Swimming pool .....	10
Doctors' Offices/Healthcare Facilities .....	10



Project carried out with the contribution of the





## Arrival at the facility

### Private/public parking

Presence of private parking	NO
Public parking nearby	YES with n. 3 places reserved for the disabled approx. 40 meters
Type of public car park	asphalt
	

### Pathway from the parking lot to the main entrance

Pathway from the car park to the entrance	Flat
There are markers and tactile maps	NO
Usable door/entrance width	more than 90 cm
Access to the factory	via 2 ramps: the first length 30 cm, width 140 cm, slope 26%; second length 215 cm, width 136 cm, gradient 8%





## Reception

Umbrella booking system	<input type="checkbox"/> Via web <input checked="" type="checkbox"/> By phone <input checked="" type="checkbox"/> On-site
Presence of multilingual staff	YES
Presence of plant plan with key to services available	NO
Presence of visuo-tactile map	NO
Bulletin board/information panels at an average height of 130 cm in a well-lit area	NO

Project carried out with the contribution of the





and font size at least 14 dpi with a contrast ratio greater than 4.5:1	
The staff attended training courses on welcoming people with different disabilities	NO

### Bar/restaurant

Type of venue	Bar
Access to the premises	See first ramp of the entrance
Usable door/entrance width	more than 90 cm
Bar counter	more than 100 cm
Types of tables	4-legged
Space underneath the tables from the floor	70 cm
Multilingual menu	YES
Menus with large print fonts	NO
Braille menu	NO
Table service for people with disabilities	NO
Availability of gluten-free food	<input type="checkbox"/> bread <input type="checkbox"/> pasta <input type="checkbox"/> biscuits <input checked="" type="checkbox"/> ice cream <input checked="" type="checkbox"/> Pre-packaged foods





## Internal Pathways and common services

### Internal Pathways




Indicate whether the pathways connecting the entrance to the beach are flat or with ramps in addition to those already described	Obstacle-free paths
--	---------------------

### Toilet and shower accessible to guests with reduced mobility

Number <b>of toilets</b> accessible/usable by guests with reduced mobility	1
Access to the premises	by ramp length 339 cm, width 98 cm, slope 11%
Usable width of the entrance door	90 cm
Toilet height	50 cm
Open front toilet seat	NO
Support handles	Missing
Flexible hand shower at the side of the toilet	NO
Free space on the sides of the toilet	left 22 cm right more than 90 cm frontal more than 90 cm
Electric doorbell/phone	YES
Washbasin with space underneath for wheelchair	63 cm
Height from the ground on the bottom edge of the mirror	135 cm
Baby changing table	NO





	
	<p style="text-align: center;">toilet</p>
<p>Accessible <b>shower</b> available for guests with reduced mobility</p>	<p>YES in common with the toilet room</p>
<p>Useful width of the door/entrance gate if separated from the toilet room</p>	<p>90 cm</p>
<p>Shower type</p>	<p>open-type</p>
<p>Floor-level shower</p>	<p>YES</p>
<p>Shower chair</p>	<p>missing</p>
<p>Grab bar</p>	<p>YES</p>
<p>Presence of shower head or ups and downs</p>	<p>Sliding rails with lowest point height 161 cm</p>
<p>Electric doorbell/phone</p>	<p>NO</p>





	shower
---	--------

### Changing room

Accessible changing room available for guests with reduced mobility	YES
Access to the premises	First ramp of the entrance
Usable door/entrance width	90 cm
Size of the dressing room	width 116 cm and depth 118 cm – measurements taken by calculating the internal cabinets (see photos)
Presence of a cot	NO
Coat rack height from the ground	167 cm





	<p>dressing room</p>
--	----------------------

### Beach


Type of beach	sand
Access to the beach	Flat
Walkway to reach the umbrellas	YES
Type of walkway	PVC
Walkway width	90 cm
Removable Platform between the walkway and the umbrella station to facilitate the passage and parking wheelchair	NO





Amphibious beach chair available for helping people with reduced mobility to enjoy swimming (owned by the establishment or by association)	YES
--	-----

### Children's play area

Children's play area	inaccessible to children with reduced mobility due to sandy bottom
There are games for children with reduced mobility	NO
	Playground





## Swimming pool

The property has a swimming pool	YES
Access to the swimming pool	Flat
Useful width of the entrance gate	more than 90 cm
Access to the pool	with ladder
Bathing aids for guests with reduced mobility	Not present
	

## Doctors' Offices/Healthcare Facilities

Hospitals near the facility	<b>Ospedale Versilia</b> SS1 Via Aurelia n. 335 55049 Lido di Camaiore LU Tel. 0584/6051
Other Healthcare Facilities	<b>Distretto Sanitario ASL n. 12</b> Viareggio Via Sant'Elme, 30 Tel. 058483873 <b>Croce Verde</b> Viale Italice, ang. via Risorgimento Tel. 058484013 Free First Aid for white codes <b>Night Medical Guard</b> Tel. 0584 83896 (h. 20-8) <b>Misericordia</b> Via P. I. da Carrara, 32 Tel. 0584752133/0584 752149



Project promoted by



**Regione Toscana**

---

	<p><b>Medical service "San Camillo" Nursing Home</b> Via P.I. da Carrara, 37 Tel. 0584 7391</p> <p><b>Dialysis service c/o Croce Verde</b> Viale Italiceo, corner via isorgimento Tel.058484013 affiliated with AUSL</p>
--	--

**TESTED BY: Handy Superabile Social Promotion Association in summer 2023**

---

Project carried out with the contribution of the



**Presidenza del  
Consiglio dei Ministri**  
Ministro per la disabilità