



Bathing establishment fact sheet

Beach establishment name	LA CICALA
Address	Via della Pineta , 219
City	PARTACCIA (MS)
Contacts	+39 0585 634754
Website	https://www.facebook.com/BagnoLaCICALA1978/

TESTED BY: [Handy Superabile Social Promotion Association](#) in summer 2023

Please note The following information refers to the verification date reported at the bottom of each sheet. The Association is not responsible for any significant changes made by the facility after the visit.

Summary

Bathing establishment fact sheet	1
Arrival at the facility	2
Private/public parking.....	2
Pathway from the parking lot to the main entrance	2
Reception.....	3
Bar/Restaurant.....	4
Internal pathways and common services	5
Internal routes	5
Toilets and showers accessible to guests with reduced mobility	5
Changing room	7
Beach.....	8
Children's play area	9
Pool.....	9
Medical offices/healthcare facilities.....	9


Project realized with the contribution of the





Arrival at the facility

Private/public parking


Presence of private parking	NO
Type of private parking lot	not present
Presence of parking space reserved for disabled people	NO
Public parking nearby	The adjacent public car park does not have spaces reserved for disabled people, but approximately 150 metres along the main road there is a public car park with 1/2 spaces reserved for disabled people.
Type of public parking lot background	asphalt
	Public parking adjacent to the entrance

Pathway from the parking lot to the main entrance

Route from the parking lot to the entrance	From the public car park via connecting ramps from the road surface to the sidewalk. The entrance is accessible via a ramp with a 7% gradient
There are indicators and tactile maps	NO





Usable width of door/entrance opening	greater than 90 cm
	Factory entrance

Reception

Umbrella reservation system	<input type="checkbox"/> Via web <input checked="" type="checkbox"/> By phone <input checked="" type="checkbox"/> On site
Presence of multilingual staff	YES
Presence of plant plan with legend of services present	NO
Presence of a visual-tactile map	NO
Noticeboard/Information Panels at an average height of 130 cm in a well-lit area and with a character size of at least 14 dpi with a contrast ratio greater than 4.5:1	NO
The staff has attended training courses on welcoming people with different disabilities	NO





Bar/Restaurant

Type of premises	Refreshment point
Access to the premises	via 2 ramps: the first length 24 cm, width 90 cm, slope 10%; second length 65 cm, width 90 cm, slope 15%
Usable width of door/entrance opening	greater than 90 cm
Bar counter	greater than 100 cm
Type of tables	with central support
Space under the floor tables	greater than 65 cm
Multilingual menu	YES
Large print menu	NO
Braille menu	NO
Table service for people with disabilities	YES
Availability of food for celiacs	<input type="checkbox"/> bread <input type="checkbox"/> pasta <input type="checkbox"/> cookies <input checked="" type="checkbox"/> ice creams <input type="checkbox"/> pre-packaged foods





Internal pathways and common services

Internal pathways

Indicate whether the entrance-beach connection paths are flat or have ramps in addition to those already described	obstacle-free paths
--	---------------------



Toilets and showers accessible to guests with reduced mobility

Number of toilets accessible/usable by guests with reduced mobility	1
Access to the premises	via difference in height cm gradient 5/6%
Usable width of entrance door	87 cm
Toilet height	50 cm
Toilet seat with open front tooth	YES
Support handles	to the right of the toilet
Flexible shower next to the toilet	YES
Free space on the sides of the toilet	left 23 cm To the right greater than 90 cm front greater than 90 cm

Project realized with the contribution of the






Electric bell/telephone	YES
Sink with space underneath for wheelchair access	70 cm
Height from ground to lower edge of mirror	sufficient for use by a person in a wheelchair
Baby changing table	NO
	
Shower accessible to guests with reduced mobility available	YES in common with the toilet room
Shower type	open type
Floor level shower	YES
Shower chair	wall folding
Support handle	YES
Presence of shower head or shower rail	up and down with lowest point reachable by a seated person
Electric bell/telephone	YES



Project promoted by



Regione Toscana



Changing room

Locker room accessible to guests with reduced mobility available	NO
--	----



Project realized with the contribution of the



Presidenza del
Consiglio dei Ministri
Ministro per la disabilità



Beach

Beach type	sand
Beach access	on the flat
Walkway to reach the umbrellas	YES
Type of walkway	wood
Width of the walkway	95 cm
	
Also removable platform between the walkway and the umbrella position to facilitate passage and parking with the wheelchair	YES
Amphibian chair available for bathing people with reduced mobility, owned or through a bathing association	YES





Children's play area

Children's play area	accessible to children with reduced mobility
There are games for children with reduced mobility	NO
	

Pool

The property has a swimming pool	NO
----------------------------------	----

Medical offices/healthcare facilities

Hospitals near the facility	NOA NEW APUANE HOSPITAL Via Enrico Mattei, 2, 54100 Marina di Massa MS tel.: +39 0585 4931
Other health facilities	TOURIST MEDICAL GUARD Locality Partaccia via delle Pinete 197/b Marina di Massa Tel.: +39 335 8001617

TESTED BY: Handy Superabile Social Promotion Association in summer 2023

Project realized with the contribution of the

