



Bathing establishment Fact Sheet

Bathhouse name	AEOLUS
Address	Viale Roma,110
City	Marina di Pietrasanta (Lu)
Contacts	Tel. +39 3383985261
Website	Not detected

TESTED BY: [Handy Superabile - Social Promotion Association](#) in summer 2023

Please note The following information refers to the verification date shown at the bottom of each card. **The Association** is not responsible for any significant changes made by the property after the visit.

Summary

Bathing establishment Fact Sheet	1
Arrival at the facility.....	2
Private/public parking.....	2
Pathway from the parking lot to the main entrance	3
Reception.....	3
Bar/restaurant	4
Internal Pathways and common services.....	5
Internal Pathways	5
Toilet and shower accessible to guests with reduced mobility	5
Changing room	7
Beach.....	7
Children's play area	8
Swimming pool	8
Doctors' Offices/Healthcare Facilities	9

Project carried out with the contribution of the






Arrival at the facility


Private/public parking

Presence of private parking	YES
Type of private car park	gravel
Presence of a parking space reserved for people with disabilities in the private car park	NO
Public parking nearby	YES
Type of public car park	asphalt
Presence of a parking space reserved for people with disabilities in the public car park	YES





Pathway from the parking lot to the main entrance

Pathway from the car park to the entrance	Flat
There are markers and tactile maps	NO
Usable door/entrance width	more than 90 cm
	

Reception

Umbrella booking system	<input type="checkbox"/> Via web <input checked="" type="checkbox"/> By phone <input checked="" type="checkbox"/> On-site
Presence of multilingual staff	Not detected
Presence of plant plan with key to services available	NO
Presence of visuo-tactile map	NO
Bulletin board/information panels at an average height of 130 cm in a well-lit area	NO





and font size at least 14 dpi with a contrast ratio greater than 4.5:1	
The staff attended training courses on welcoming people with different disabilities	NO

Bar/restaurant

Type of venue	Bar/restaurant
Access to the premises	by ramp length 501 cm, width 171 cm, slope 12.3% and handrails on both sides
Usable door/entrance width	more than 90 cm
Bar counter	more than 100 cm
Types of tables	with central support
Space underneath the tables from the floor	69 cm
Multilingual menu	YES
Menus with large print fonts	YES
Braille menu	NO
Table service for people with disabilities	YES
Availability of gluten-free food	<input checked="" type="checkbox"/> bread <input checked="" type="checkbox"/> pasta <input checked="" type="checkbox"/> biscuits <input checked="" type="checkbox"/> ice cream <input type="checkbox"/> Pre-packaged foods





Internal Pathways and common services

Internal Pathways

Indicate whether the pathways connecting the entrance to the beach are flat or with ramps in addition to those already described	Obstacle-free paths
--	---------------------


Toilet and shower accessible to guests with reduced mobility

Number of toilets accessible/usable by guests with reduced mobility	1
Access to the premises	via the same ramp leading to the restaurant: length 501 cm, width 171 cm, slope 12.3%
Usable width of the entrance door	84 cm
WC height	46.5 cm
Open front toilet seat	YES
Support handles	to the left of the toilet
Flexible hand shower at the side of the toilet	YES
Free space on the sides of the toilet	left more than 90 cm right Choose an item.

Project carried out with the contribution of the





	frontal more than 90 cm
Electric doorbell/phone	YES
Washbasin with space underneath for wheelchair	62 cm
Height from the ground on the bottom edge of the mirror	Missing mirror
Baby changing table	NO
	
	
Accessible shower available for guests with reduced mobility	NO







Changing room

Accessible changing room available for guests with reduced mobility	NO
---	----

Beach

Type of beach	sand
Access to the beach	Flat
Walkway to reach the umbrellas	YES
Type of walkway	PVC
Walkway width	100 cm
	
Removable Platform between the walkway and the umbrella station to facilitate the passage and parking wheelchair	YES
Amphibious beach chair available for helping people with reduced mobility to enjoy swimming (owned by the establishment or by association)	YES





Children's play area

Children's play area	missing
----------------------	---------

Swimming pool

The property has a swimming pool	YES for adults and children
Access to the swimming pool	through a first ramp 150 cm long, 79 cm wide, 7.2% slope and foot wash with descent and ascent and subsequent 4 steps that can be overcome via a ramp about 500 cm long, more than 90 cm wide and slope about 9/10%
Useful width of the entrance gate	more than 90 cm
Access to the pool	with ladder
Tank depth	60 cm children - 120 cm adults
Bathing aids for guests with reduced mobility	Not present





Doctors' Offices/Healthcare Facilities

Hospitals near the facility	Ospedale Versilia SS1 Via Aurelia n. 335 55049 Lido di Camaiore LU Tel. 0584/6051
Other Healthcare Facilities	<p>Distretto Sanitario ASL 12 Pietrasanta Via Martiri S. Anna 11 Tel. 05846058823</p> <p>Croce Verde Via Risorgimento, 1 Forte dei Marmi Tel. 058484013 free dialysis and first aid service for white codes</p> <p>Emergency medical service Via Martiri S. Anna Tel. 0584 616774</p> <p>Misericordia Via Mazzini Pietrasanta Tel. 058470055</p>



Project promoted by



Regione Toscana

	<p>Medical service "San Camillo" Nursing Home Via P.I. da Carrara, 37 Tel. 0584 7391</p> <p>Dialysis service c/o Croce Verde Viale Italico at the corner of Via Risorgimento Forte dei Marmi Tel. 058484013 affiliated with AUSL</p>
--	--

TESTED BY: Handy Superabile Social Promotion Association in summer 2023

Project carried out with the contribution of the



**Presidenza del
Consiglio dei Ministri**
Ministro per la disabilità