



## Bathing establishment Fact Sheet

Bathhouse name	ANNA
Address	Viale Roma,7
City	Marina di Pietrasanta (Lu)
Contacts	Tel. +39 0584 20997
Website	Not detected

**TESTED BY:** [Handy Superabile - Social Promotion Association](#) in summer 2023

**Please note** The following information refers to the verification date shown at the bottom of each card. **The Association** is not responsible for any significant changes made by the property after the visit.

### Summary

Bathing establishment Fact Sheet .....	1
Arrival at the facility.....	2
Private/public parking.....	2
Pathway from the parking lot to the main entrance .....	3
Reception.....	4
Bar/restaurant .....	4
Internal Pathways and common services.....	4
Internal Pathways .....	4
Toilet and shower accessible to guests with reduced mobility .....	5
Changing room .....	6
Beach.....	7
Children's play area .....	8
Swimming pool .....	8
Doctors' Offices/Healthcare Facilities .....	8



Project carried out with the contribution of the






**Arrival at the facility**



**Private/public parking**

Presence of private parking	YES
Type of private car park	gravel
Presence of a parking space reserved for people with disabilities in the private car park	NO
Public parking nearby	YES
Type of public car park	asphalt
Presence of a parking space reserved for people with disabilities in the public car park	YES
	





**Pathway from the parking lot to the main entrance**

Pathway from the car park to the entrance	by ramp length cm, width cm slope %
There are markers and tactile maps	NO
Usable door/entrance width	more than 90 cm
	





## Reception

Umbrella booking system	<input type="checkbox"/> Via web <input checked="" type="checkbox"/> By phone <input checked="" type="checkbox"/> On-site
Presence of multilingual staff	Not detected
Presence of plant plan with key to services available	NO
Presence of visuo-tactile map	NO
Bulletin board/information panels at an average height of 130 cm in a well-lit area and font size at least 14 dpi with a contrast ratio greater than 4.5:1	NO
The staff attended training courses on welcoming people with different disabilities	NO

## Bar/restaurant

Type of venue	missing
---------------	---------

## Internal Pathways and common services



### Internal Pathways

Indicate whether the pathways connecting the entrance to the beach are flat or with ramps in addition to those already described	Obstacle-free paths
----------------------------------------------------------------------------------------------------------------------------------	---------------------





**Toilet and shower accessible to guests with reduced mobility**

Number <b>of toilets</b> accessible/usable by guests with reduced mobility	1
Access to the premises	ramp length 60 cm, width 150 cm, slope 7%
Usable width of the entrance door	88 cm and ramp
WC height	49 cm
Open front toilet seat	YES
Support handles	on both sides
Flexible hand shower at the side of the toilet	NO
Free space on the sides of the toilet	left 41 cm right more than 90 cm frontal 90 cm
Electric doorbell/phone	YES
Washbasin with space underneath for wheelchair	65 cm
Height from the ground on the bottom edge of the mirror	128 cm
Baby changing table	NO
	





<p>Accessible <b>shower</b> available for guests with reduced mobility</p>	<p>NO but there is an outdoor shower without a canopy</p>



**Changing room**

<p>Accessible changing room available for guests with reduced mobility</p>	<p>YES</p>
<p>Access to the premises</p>	<p>By means of a connecting ramp</p>
<p>Usable door/entrance width</p>	<p>90 cm</p>
<p>Size of the dressing room</p>	<p>width 152 cm and depth 184 cm</p>
<p>Presence of a cot</p>	<p>NO</p>
<p>Coat rack height from the ground</p>	<p>167 cm</p>





**Beach**

Type of beach	sand
Access to the beach	Flat
Walkway to reach the umbrellas	YES
Type of walkway	cement
Walkway width	100 cm
	
Removable Platform between the walkway and the umbrella station to facilitate the passage and parking wheelchair	YES
Amphibious beach chair available for helping people with reduced mobility to enjoy swimming (owned by the establishment or by association)	YES





**Children's play area**

Children's play area	missing
----------------------	---------

**Swimming pool**

The property has a swimming pool	NO
----------------------------------	----

**Doctors' Offices/Healthcare Facilities**

Hospitals near the facility	<b>Ospedale Versilia SS1</b> Via Aurelia n. 335 55049 Lido di Camaiore LU Tel. 0584/6051
Other Healthcare Facilities	<b>Distretto Sanitario ASL 12 Pietrasanta</b> Via Martiri S. Anna 11 Tel. 05846058823 <b>Croce Verde</b> Via Risorgimento, 1 Forte dei Marmi Tel. 058484013 free dialysis and first aid service for white codes <b>Emergency medical service</b> Via Martiri S. Anna Pietrasanta Tel. 0584 616774 <b>Misericordia</b> Via Mazzini Pietrasanta Tel. 058470055



Project promoted by



**Regione Toscana**

---

	<p><b>Medical service Casa di cura "San Camillo"</b> Via P.I. da Carrara, Forte dei Marmi 37 Tel. 0584 7391</p> <p><b>Dialysis service c/o Croce Verde</b> Viale Italico at the corner of Via Risorgimento Forte dei Marmi Tel. 058484013 affiliated with AUSL</p>
--	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**TESTED BY: Handy Superabile Social Promotion Association in summer 2023**

---

Project carried out with the contribution of the



**Presidenza del  
Consiglio dei Ministri**  
Ministro per la disabilità