



## Bathing establishment Fact Sheet

Bathhouse name	DAISY
Address	Via Lungomare Roma,58
City	Marina di Pietrasanta (Lu)
Contacts	Tel +39 0584 20893 Email <a href="mailto:bagnodaisy88@gmail.com">bagnodaisy88@gmail.com</a>
Website	Not detected

**TESTED BY:** [Handy Superabile - Social Promotion Association](#) in summer 2023

**Please note** The following information refers to the verification date shown at the bottom of each card. **The Association** is not responsible for any significant changes made by the property after the visit.

### Summary

Bathing establishment Fact Sheet .....	1
Tel 0584 20893 Email <a href="mailto:bagnodaisy88@gmail.com">bagnodaisy88@gmail.com</a> .....	1
Arrival at the facility .....	2
Private/public parking.....	2
Pathway from the parking lot to the main entrance .....	2
Reception.....	3
Bar/restaurant .....	4
Internal Pathways and common services.....	5
Internal Pathways .....	5
Toilet and shower accessible to guests with reduced mobility .....	5
Changing room .....	7
Beach.....	8
Children's play area .....	9
Swimming pool .....	9
Doctors' Offices/Healthcare Facilities .....	10

Project carried out with the contribution of the





**Arrival at the facility**

**Private/public parking**

Presence of private parking	YES
Type of private car park	gravel
Presence of parking space reserved for people with disabilities	NO
Public parking nearby	YES
Type of public car park	asphalt
	

**Pathway from the parking lot to the main entrance**

Pathway from the car park to the entrance	flat on a gravel and sparse porphyry surface that can make it difficult for wheelchair users to move around
There are markers and tactile maps	NO
Usable door/entrance width	more than 90 cm





**Reception**

Umbrella booking system	<input type="checkbox"/> Via web <input checked="" type="checkbox"/> By phone <input checked="" type="checkbox"/> On-site
Presence of multilingual staff	YES
Presence of plant plan with key to services available	NO
Presence of visuo-tactile map	NO
Bulletin board/information panels at an average height of 130 cm in a well-lit area and font size at least 14 dpi with a contrast ratio greater than 4.5:1	NO
The staff attended training courses on welcoming people with different disabilities	NO





**Bar/restaurant**

Type of venue	Snack bar
Access to the premises Usable door/entrance width Bar counter Types of tables Space underneath the tables from the floor Multilingual menu Menus with large print fonts Braille menu Table service for people with disabilities Availability of gluten-free food	Flat more than 90 cm more than 100 cm 4-legged 63 cm Not detected NO NO YES <input checked="" type="checkbox"/> bread <input checked="" type="checkbox"/> pasta <input type="checkbox"/> biscuits <input checked="" type="checkbox"/> ice cream <input type="checkbox"/> Pre-packaged foods





**Internal Pathways and common services**

**Internal Pathways**



Indicate whether the pathways connecting the entrance to the beach are flat or with ramps in addition to those already described	Obstacle-free paths
--	---------------------

**Toilet and shower accessible to guests with reduced mobility**

Number <b>of toilets</b> accessible/usable by guests with reduced mobility	1
Access to the premises	Flat
Usable width of the entrance door	more than 90 cm
Toilet height	50 cm
Open front toilet seat	YES
Support handles	on both sides
Flexible hand shower at the side of the toilet	NO






Free space on the sides of the toilet	left more than 90 cm right 22 cm frontal 57 cm
Electric doorbell/phone	YES
Washbasin with space underneath for wheelchair	64 cm
Height from the ground on the bottom edge of the mirror	not sufficient for use by a person in a wheelchair
Baby changing table	NO
	
reduced mobility	
Access to the shower room if separated from the toilet room	Flat
Useful width of the door/entrance gate if separated from the toilet room	more than 80 cm
Shower type	with 70 cm opening box and dimensions 63 X 70 cm cm
Floor-level shower	NO with 13 cm high step
Shower chair	missing
Grab bar	missing
Presence of shower head or ups and downs	fixed shower head
Electric doorbell/phone	NO





**Changing room**

Accessible changing room available for guests with reduced mobility	YES shared with shower inaccessible with confined spaces
Access to the premises	Flat
Usable door/entrance width	more than 80 cm
Size of the dressing room	width 80 cm and depth 130 cm
Presence of a cot	NO
Coat rack height from the ground	165 cm






**Beach**

Type of beach	sand
Access to the beach	Flat
Walkway to reach the umbrellas	YES
Type of walkway	cement
Walkway width	90 cm
	
Removable Platform between the walkway and the umbrella station to facilitate the passage and parking wheelchair	YES
Amphibious beach chair available for helping people with reduced mobility to enjoy swimming (owned by the establishment or by association)	YES






**Children's play area**

Children's play area	Not detected
----------------------	--------------

**Swimming pool**

The property has a swimming pool	YES
Access to the swimming pool	by foot washer with step
Useful width of the entrance gate	more than 90 cm
Access to the pool	with ladder
Bathing aids for guests with reduced mobility	Not present





**Doctors' Offices/Healthcare Facilities**

Hospitals near the facility	<b>Ospedale Versilia SS1</b> Via Aurelia n. 335 55049 Lido di Camaiore LU Tel. 0584/6051
Other Healthcare Facilities	<b>Distretto Sanitario ASL 12 Pietrasanta</b> Via Martiri S. Anna 11 Tel. 05846058823 <b>Croce Verde</b> Via Risorgimento, 1 Forte dei Marmi Tel. 058484013 free dialysis and first aid service for white codes

Project carried out with the contribution of the



Project promoted by



**Regione Toscana**

---

	<p><b>Emergency medical service</b> Via Martiri S. Anna Tel. 0584 616774</p> <p><b>Misericordia</b> Via Mazzini Pietrasanta Tel. 058470055</p> <p><b>Medical service "San Camillo" Nursing Home</b> Via P.I. da Carrara, 37 Tel. 0584 7391</p> <p><b>Dialysis service c/o Croce Verde</b> Viale Italoico at the corner of Via Risorgimento Forte dei Marmi Tel. 058484013 affiliated with AUSL</p>
--	--

TESTED BY: [Handy Superabile Social Promotion Association](#) in summer 2023

---

Project carried out with the contribution of the



**Presidenza del  
Consiglio dei Ministri**  
Ministro per la disabilità