



Bathing establishment Fact Sheet

Bathhouse name	ERMIONE
Address	Via Lungomare Roma n. 183
City	Marina di Pietrasanta (Lu)
Contacts	+39 0584745906 - +39 058420259
Website	Not detected

TESTED BY: [Handy Superabile - Social Promotion Association](#) in summer 202

Please note The following information refers to the verification date shown at the bottom of each card. **The Association** is not responsible for any significant changes made by the property after the visit.

Summary

Bathing establishment Fact Sheet	1
Arrival at the facility.....	2
Private/public parking.....	2
Pathway from the parking lot to the main entrance	2
Reception.....	3
Bar/restaurant	4
Internal Pathways and common services.....	4
Internal Pathways	4
Toilet and shower accessible to guests with reduced mobility	5
Changing room	7
Beach.....	8
Children's play area	9
Swimming pool	10
Doctors' Offices/Healthcare Facilities	10

Project carried out with the contribution of the





Arrival at the facility

Private/public parking

Presence of private parking	YES
Type of private car park	gravel
Presence of parking space reserved for people with disabilities	YES
Public parking nearby	YES
Type of public car park	asphalt
	

Pathway from the parking lot to the main entrance

Pathway from the car park to the entrance	flat on a gravel surface that can make it difficult for wheelchair users to move around and entrance via a slightly sloping ramp with a handrail on the left
There are markers and tactile maps	NO
Usable door/entrance width	more than 90 cm







Reception

Umbrella booking system	<input type="checkbox"/> Via web <input checked="" type="checkbox"/> By phone <input checked="" type="checkbox"/> On-site
Presence of multilingual staff	Not detected
Presence of plant plan with key to services available	NO
Presence of visuo-tactile map	NO
Bulletin board/information panels at an average height of 130 cm in a well-lit area and font size at least 14 dpi with a contrast ratio greater than 4.5:1	NO
The staff attended training courses on welcoming people with different disabilities	NO





Bar/restaurant

Type of venue	missing
---------------	---------

Internal Pathways and common services

Internal Pathways

Indicate whether the pathways connecting the entrance to the beach are flat or with ramps in addition to those already described	Obstacle-free paths
--	---------------------





Toilet and shower accessible to guests with reduced mobility



Number of toilets accessible/usable by guests with reduced mobility	1
Access to the premises	by ramp length 350 cm, width 100 cm, gradient 3.2%
Usable width of the entrance door	86 cm
Toilet height	41 cm
Open front toilet seat	NO
Support handles	to the left of the toilet
Flexible hand shower at the side of the toilet	NO
Free space on the sides of the toilet	left 25 cm right more than 90 cm frontal more than 90 cm
Electric doorbell/phone	NO
Washbasin with space underneath for wheelchair	63 cm
Height from the ground on the bottom edge of the mirror	125 cm
Baby changing table	NO

Project carried out with the contribution of the









Accessible shower available for guests with reduced mobility	YES, there are two shower rooms, one shared with the toilet
Access to the shower room if separated from the toilet room	Flat
Useful width of the door/entrance gate if separated from the toilet room	86 cm
Shower type	open-type
Floor-level shower	YES
Shower chair	missing
Grab bar	missing
Presence of shower head or ups and downs	Sliding rails with lowest point height in the toilet room and in the separate room 142 cm
Electric doorbell/phone	NO
	

Changing room

Accessible changing room available for guests with reduced mobility	YES, shared with the shower room
Access to the premises	by ramp length 350 cm, width 100 cm, slope 3.2%
Usable door/entrance width	86 cm





Size of the dressing room	width 183 cm and depth 181 cm
Presence of a cot	NO
Coat rack height from the ground	143 cm
	

Beach

Type of beach	sand
Access to the beach	by ramp length 668 cm, width 125 cm, slope 4.5%
Walkway to reach the umbrellas	YES
Type of walkway	Mixed PVC/cement
Walkway width	90 cm





<p>Removable Platform between the walkway and the umbrella station to facilitate the passage and parking wheelchair</p>	<p>YES</p>
<p>Amphibious beach chair available for helping people with reduced mobility to enjoy swimming (owned by the establishment or by association)</p>	<p>YES</p>

Children's play area

<p>Children's play area</p>	<p>missing</p>
-----------------------------	----------------





Swimming pool

The property has a swimming pool	NO
----------------------------------	----

Doctors' Offices/Healthcare Facilities

Hospitals near the facility	Ospedale Versilia , SS 1, 335, 55049 Camaione LU 05846051
Other Healthcare Facilities	Distretto Sanitario ASL 12 Pietrasanta Via Martiri S. Anna 11 Tel. 05846058823 Croce Verde Via Risorgimento, 1 Forte dei Marmi Tel. 058484013 free dialysis and first aid service for white codes Emergency medical service Via Martiri S. Anna Tel. 0584 616774 Misericordia Via Mazzini Pietrasanta Tel. 058470055 Medical service "San Camillo" Nursing Home Via P.I. da Carrara, 37 Tel. 0584 7391 Dialysis service c/o Croce Verde Viale Italico at the corner of Via Risorgimento Forte dei Marmi Tel. 058484013 affiliated with AUSL

TESTED BY: **Handy Superabile Social Promotion Association in summer 2023**

