



Bathing establishment Fact Sheet

Bathhouse name	Lucia
Address	Lungomare 57
City	Marina di Pietrasanta (Lu)
Contacts	Tel. +39 058421553 - +39 338 357 0001 bagnolucia57@gmail.com
Website	Not detected

TESTED BY: [Handy Superabile - Social Promotion Association](#) in summer 2023

Please note The following information refers to the verification date shown at the bottom of each card. **The Association** is not responsible for any significant changes made by the property after the visit.

Summary

Bathing establishment Fact Sheet	1
Arrival at the facility	2
Private/public parking.....	2
Pathway from the parking lot to the main entrance	3
Reception.....	3
Bar/restaurant	4
Internal Pathways and common services.....	5
Internal Pathways	5
Toilet and shower accessible to guests with reduced mobility	6
Changing room	8
Beach.....	8
Children's play area	10
Swimming pool	10
Doctors' Offices/Healthcare Facilities	11

Project carried out with the contribution of the






Project promoted by



Regione Toscana

Arrival at the facility

Private/public parking

Presence of private parking	YES
Presence of parking space reserved for people with disabilities	NO
Type of parking surface	GRAVEL
Public parking nearby	YES
	
	



Project carried out with the contribution of the



**Presidenza del
Consiglio dei Ministri**
Ministro per la disabilità



Pathway from the parking lot to the main entrance

Pathway from the car park to the entrance	Flat
There are markers and tactile maps	NO
Usable door/entrance width	more than 90 cm
	

Reception

Umbrella booking system	<input type="checkbox"/> Via web <input checked="" type="checkbox"/> By phone <input checked="" type="checkbox"/> On-site
Presence of multilingual staff	YES
Presence of plant plan with key to services available	NO
Presence of visuo-tactile map	NO
Bulletin board/information panels at an average height of 130 cm in a well-lit area	NO






and font size at least 14 dpi with a contrast ratio greater than 4.5:1	
The staff attended training courses on welcoming people with different disabilities	NO

Bar/restaurant

Type of venue	Bar/restaurant
Access to the premises	with a 20 cm high step that can be overcome with a short detachable wooden connection ramp
Usable door/entrance width	more than 90 cm
Bar counter	height greater than 100 cm
Types of tables	with central support
Space underneath the tables from the floor	71 cm
Multilingual menu	YES
Menus with large print fonts	NO
Braille menu	NO
Table service for people with disabilities	YES
Availability of gluten-free food	<input type="checkbox"/> bread <input type="checkbox"/> pasta <input type="checkbox"/> biscuits <input checked="" type="checkbox"/> ice cream <input type="checkbox"/> Pre-packaged foods





Internal Pathways and common services

Internal Pathways



Indicate whether the pathways connecting the entrance to the beach are flat or with ramps in addition to those already described

Obstacle-free paths





Toilet and shower accessible to guests with reduced mobility

Number of toilets accessible/usable by guests with reduced mobility	1
Access to the premises	by ramp length 368 cm, width 150 cm, slope 3.8 % and handrail on the right
Usable width of the entrance door	90 cm
Toilet height	49 cm
Open front toilet seat	YES
Support handles	on both sides of the toilet
Flexible hand shower at the side of the toilet	NO
Free space on the sides of the toilet	left 30 approximately right more than 90 cm frontal more than 90 cm
Electric doorbell/phone	YES
Washbasin with space underneath for wheelchair	65 cm
Height from the ground on the bottom edge of the mirror	130 cm
Baby changing table	YES
	







	
<p>Accessible shower available for guests with reduced mobility</p>	<p>Yes in common with the toilet room</p>
<p>Shower type</p>	<p>open-type</p>
<p>Floor-level shower</p>	<p>YES</p>
<p>Shower chair</p>	<p>wall-mounted folding 35 X 39 cm high 49 cm</p>
<p>Grab bar</p>	<p>YES</p>
<p>Presence of shower head or ups and downs</p>	<p>Sliding rails with lowest point height 145 cm and tap at 120 cm height</p>
<p>Electric doorbell/phone</p>	<p>YES</p>
	





Changing room

Accessible changing room available for guests with reduced mobility	YES
Access to the premises	Same ramp as the toilets
Usable door/entrance width	90 cm
Size of the dressing room	Width 175 cm and depth 180 cm
Presence of a cot	NO
Coat rack height from the ground	170 cm
	

Beach

Type of beach	sand
Access to the beach	Flat
Walkway to reach the umbrellas	YES
Type of walkway	concrete





Walkway width	100 cm
	
Removable Platform between the walkway and the umbrella station to facilitate the passage and parking wheelchair	YES
Amphibious beach chair available for helping people with reduced mobility to enjoy swimming (owned by the establishment or by association)	YES
	






Children's play area

Children's play area	Accessible to children with reduced mobility
There are games for children with reduced mobility	NO

Swimming pool

The property has a swimming pool	YES for adults and children
Access to the swimming pool	By means of a small step; Foot washing tub on the side with 6.5 cm high step
Useful width of the entrance gate	more than 80 cm
Access to the pool	with ladder
Tank depth	For adults 160 cm and for children 80 cm
Bathing aids for guests with reduced mobility	Not present





Doctors' Offices/Healthcare Facilities

Hospitals near the facility	Ospedale Versilia SS1 Via Aurelia n. 335 55049 Lido di Camaiore LU Tel. 0584/6051
Other Healthcare Facilities	<p>Distretto Sanitario ASL 12 Pietrasanta Via Martiri S. Anna 11 Tel. 05846058823</p> <p>Croce Verde Via Risorgimento, 1 Forte dei Marmi Tel. 058484013 free dialysis and first aid service for white codes</p> <p>Emergency medical service Via Martiri S. Anna Tel. 0584 616774</p> <p>Misericordia Via Mazzini Pietrasanta Tel. 058470055</p> <p>Medical service "San Camillo" Nursing Home Via P.I. da Carrara, 37 Tel. 0584 7391</p>



Project promoted by



Regione Toscana

	Dialysis service c/o Croce Verde , Viale Italiceo at the corner of Via Risorgimento, Forte dei Marmi Tel. 058484013 affiliated with ASL
--	--

TESTED BY: [Handy Superabile Social Promotion Association](#) in summer 2023

Project carried out with the contribution of the



**Presidenza del
Consiglio dei Ministri**
Ministro per la disabilità