



## Bathing establishment Fact Sheet

Bathhouse name	MOTRONE
Address	Viale Roma 107 (Loc. Motrone)
City	Marina di Pietrasanta (Lu)
Contacts	+39 335 226685 - <a href="mailto:b.motrone@gmail.com">b.motrone@gmail.com</a>
Website	<a href="https://www.bagnomotroneversilia.it/">https://www.bagnomotroneversilia.it/</a>

**TESTED BY:** [Handy Superabile - Social Promotion Association](#) in summer 2023

**Please note** The following information refers to the verification date shown at the bottom of each card. **The Association** is not responsible for any significant changes made by the property after the visit.

### Summary

Bathing establishment Fact Sheet .....	1
Arrival at the facility .....	2
Private/public parking.....	2
Pathway from the parking lot to the main entrance .....	2
Reception.....	3
Bar/restaurant .....	4
Internal Pathways and common services.....	4
Internal Pathways .....	4
Toilet and shower accessible to guests with reduced mobility .....	4
Changing room .....	6
Beach.....	7
Children's play area .....	7
Swimming pool .....	8
Doctors' Offices/Healthcare Facilities .....	8



Project carried out with the contribution of the





**Arrival at the facility**

**Private/public parking**

Presence of private parking	YES
Type of private car park	Fine gravel
Presence of a parking space reserved for people with disabilities in the private car park	YES
Public parking nearby	YES with parking spaces reserved for the disabled
Type of public car park	asphalt
Presence of a parking space reserved for people with disabilities in the public car park	YES
	

**Pathway from the parking lot to the main entrance**

Pathway from the car park to the entrance	Flat
There are markers and tactile maps	NO





Usable door/entrance width	more than 90 cm
	

**Reception**

Umbrella booking system	<input type="checkbox"/> Via web <input checked="" type="checkbox"/> By phone <input checked="" type="checkbox"/> On-site
Presence of multilingual staff	YES
Presence of plant plan with key to services available	NO
Presence of visuo-tactile map	NO
Bulletin board/information panels at an average height of 130 cm in a well-lit area and font size at least 14 dpi with a contrast ratio greater than 4.5:1	NO
The staff attended training courses on welcoming people with different disabilities	NO





**Bar/restaurant**

Type of venue	missing
---------------	---------

**Internal Pathways and common services**

**Internal Pathways**

Indicate whether the pathways connecting the entrance to the beach are flat or with ramps in addition to those already described	The path is flat but with part of the paths are on spaced slabs, even if thin, in order to reach gazebos with chairs
	

**Toilet and shower accessible to guests with reduced mobility**

Number <b>of toilets</b> accessible/usable by guests with reduced mobility	1
Access to the premises	via ramp 97 cm long, 109 cm wide, gradient approx. 24 %
Usable width of the entrance door	76 cm







WC height	50 cm
Open front toilet seat	YES
Support handles	to the left of the toilet
Flexible hand shower at the side of the toilet	NO
Free space on the sides of the toilet	left 60 cm right 26 cm frontal more than 90 cm
Electric doorbell/phone	NO
Washbasin with space underneath for wheelchair	62 cm
Height from the ground on the bottom edge of the mirror	132 cm
Baby changing table	YES
	
	





Accessible <b>shower</b> available for guests with reduced mobility	SI separated from the toilet room
Access to the shower room if separated from the toilet room	by ramp 104 cm long, 106 cm wide slope approx. 30 %
Useful width of the door/entrance gate if separated from the toilet room	81 cm
Shower type	open-type
Floor-level shower	YES
Shower chair	missing
Grab bar	YES
Presence of shower head or ups and downs	Sliding rails with lowest point height 142 cm
Electric doorbell/phone	YES
	



### Changing room

Accessible changing room available for guests with reduced mobility	NO
---	----





## Beach

Type of beach	sand
Access to the beach	Flat
Walkway to reach the umbrellas	YES
Type of walkway	wood
Walkway width	100 cm
	
Removable Platform between the walkway and the umbrella station to facilitate the passage and parking wheelchair	YES
Amphibious beach chair available for helping people with reduced mobility to enjoy swimming (owned by the establishment or by association)	YES

## Children's play area

Children's play area	missing
There are games for children with reduced mobility	NO





### Swimming pool

The property has a swimming pool	NO
----------------------------------	----

### Doctors' Offices/Healthcare Facilities

Hospitals near the facility	<b>Ospedale Versilia</b> SS1 Via Aurelia n. 335 55049 Lido di Camaiore LU Tel. 0584/6051
Other Healthcare Facilities	<b>Distretto Sanitario ASL 12 Pietrasanta</b> Via Martiri S. Anna 11 Tel. 05846058823 <b>Croce Verde</b> Via Risorgimento, 1 Forte dei Marmi Tel. 058484013 free dialysis and first aid service for white codes <b>Emergency medical service</b> Via Martiri S. Anna Tel. 0584 616774 <b>Misericordia</b> Via Mazzini Pietrasanta Tel. 058470055 <b>Medical service "San Camillo" Nursing Home</b> Via P.I. da Carrara, 37 Tel. 0584 7391 <b>Dialysis service c/o Croce Verde</b> Viale Italico at the corner of Via Risorgimento Forte dei Marmi Tel. 058484013 affiliated with AUSL

TESTED BY: **Handy Superabile Social Promotion Association in summer 2023**

