



Bathing establishment Fact Sheet

Bathhouse name	ONDA
Address	Viale Roma, 122
City	Marina di Pietrasanta (Lu)
Contacts	Tel. +39393 548 3636 - Email info@bagnonda.com
Website	https://www.bagnonda.com/

TESTED BY: [Handy Superabile - Social Promotion Association](#) in summer 2023

Please note The following information refers to the verification date shown at the bottom of each card. **The Association** is not responsible for any significant changes made by the property after the visit.

Summary

Bathing establishment Fact Sheet	1
Arrival at the facility.....	2
Private/public parking.....	2
Pathway from the parking lot to the main entrance	2
Reception.....	3
Bar/restaurant	4
Internal Pathways and common services.....	5
Internal Pathways	5
Toilet and shower accessible to guests with reduced mobility	5
Changing room	7
Beach.....	7
Children's play area	8
Swimming pool	8
Doctors' Offices/Healthcare Facilities	9

Project carried out with the contribution of the





Arrival at the facility

Private/public parking

Presence of private parking	YES
Type of private car park	gravel
Presence of parking space reserved for people with disabilities	YES
Public parking nearby	YES
Type of public car park	asphalt
	

Pathway from the parking lot to the main entrance

Pathway from the car park to the entrance	flat on a gravel surface that can make it difficult for wheelchair users to move around
There are markers and tactile maps	NO
Usable door/entrance width	more than 90 cm





Reception

Umbrella booking system	<input type="checkbox"/> Via web <input checked="" type="checkbox"/> By phone <input checked="" type="checkbox"/> On-site
Presence of multilingual staff	YES
Presence of plant plan with key to services available	NO
Presence of visuo-tactile map	NO
Bulletin board/information panels at an average height of 130 cm in a well-lit area and font size at least 14 dpi with a contrast ratio greater than 4.5:1	NO
The staff attended training courses on welcoming people with different disabilities	NO






Bar/restaurant

Type of venue	Bar/restaurant
Access to the premises	via ramp length 290 cm, width 100 cm, slope 9% and handrail on the left
Usable door/entrance width	more than 90 cm
Bar counter	more than 100 cm
Types of tables	4-legged
Space underneath the tables from the floor	69 cm
Multilingual menu	YES
Menus with large print fonts	YES
Braille menu	NO
Table service for people with disabilities	YES
Availability of gluten-free food	<input type="checkbox"/> bread <input type="checkbox"/> pasta <input type="checkbox"/> biscuits <input checked="" type="checkbox"/> ice cream <input type="checkbox"/> Pre-packaged foods





Internal Pathways and common services

Internal Pathways

Indicate whether the pathways connecting the entrance to the beach are flat or with ramps in addition to those already described	Obstacle-free paths
--	---------------------



Toilet and shower accessible to guests with reduced mobility

Number of toilets accessible/usable by guests with reduced mobility	1
Access to the premises	via the same ramp that leads to the restaurant
Usable width of the entrance door	85 cm
Toilet height	50 cm
Open front toilet seat	YES
Support handles	on both sides
Flexible hand shower at the side of the toilet	YES

Project carried out with the contribution of the





Free space on the sides of the toilet	left more than 90 cm right 10 cm frontal more than 90 cm
Electric doorbell/phone	YES
Washbasin with space underneath for wheelchair	67 cm
Height from the ground on the bottom edge of the mirror	140 cm
Baby changing table	NO
 reduced mobility	
Shower type	open-type
Floor-level shower	YES
Shower chair	missing
Grab bar	YES
Presence of shower head or ups and downs	Sliding rails with lowest point height 120 cm and tap at 110 cm
Electric doorbell/phone	YES





	<p>Shower shared with the toilet room</p>
--	---

Changing room

<p>Accessible changing room available for guests with reduced mobility</p>	<p>YES</p>
<p>Access to the premises</p>	<p>via the same ramp that leads to the toilet room</p>
<p>Usable door/entrance width</p>	<p>84 cm</p>
<p>Size of the dressing room</p>	<p>sufficient for wheelchair manoeuvring</p>
<p>Presence of a cot</p>	<p>NO</p>
<p>Coat rack height from the ground</p>	<p>160 cm</p>

Beach

<p>Type of beach</p>	<p>sand</p>
<p>Access to the beach</p>	<p>Flat</p>
<p>Walkway to reach the umbrellas</p>	<p>YES</p>
<p>Type of walkway</p>	<p>PVC</p>
<p>Walkway width</p>	<p>90 cm</p>





<p>Removable Platform between the walkway and the umbrella station to facilitate the passage and parking wheelchair</p>	<p>YES</p>
<p>Amphibious beach chair available for helping people with reduced mobility to enjoy swimming (owned by the establishment or by association)</p>	<p>YES</p>

Children's play area

<p>Children's play area</p>	<p>Not detected</p>
-----------------------------	---------------------

Swimming pool

<p>The property has a swimming pool</p>	<p>YES</p>
<p>Access to the swimming pool</p>	<p>by ramp length 175 cm, width 100 cm, gradient 11.5 %</p>
<p>Useful width of the entrance gate</p>	<p>more than 90 cm</p>
<p>Access to the pool</p>	<p>with ladder</p>





<p>Bathing aids for guests with reduced mobility</p>	<p>Not present</p>
	
	

Doctors' Offices/Healthcare Facilities

<p>Hospitals near the facility</p>	<p>Ospedale Versilia SS1 Via Aurelia n. 335 55049 Lido di Camaiore LU Tel. 0584/6051</p>
<p>Other Healthcare Facilities</p>	<p>Distretto Sanitario ASL 12 Pietrasanta Via Martiri S. Anna 11 Tel. 05846058823 Croce Verde Via Risorgimento, 1 Forte dei Marmi Tel. 058484013 free dialysis and first aid service for white codes</p>



Project promoted by



Regione Toscana

	<p>Emergency medical service Via Martiri S. Anna Tel. 0584 616774</p> <p>Misericordia Via Mazzini Pietrasanta Tel. 058470055</p> <p>Medical service "San Camillo" Nursing Home Via P.I. da Carrara, 37 Tel. 0584 7391</p> <p>Dialysis service c/o Croce Verde Viale Italicò at the corner of Via Risorgimento Forte dei Marmi Tel. 058484013 affiliated with AUSL</p>
--	---

TESTED BY: [Handy Superabile Social Promotion Association](#) in summer 2023

Project carried out with the contribution of the



**Presidenza del
Consiglio dei Ministri**
Ministro per la disabilità