



Bathing establishment Fact Sheet

Bathhouse name	ROMA FIUMETTO
Address	Viale Lungomare, 35
City	Marina di Pietrasanta (Lu)
Contacts	Tel. +39 058420909 Email info@bagnoromafiumetto.it
Website	www.bagnoromafiumetto.it/en

TESTED BY: [Handy Superabile - Social Promotion Association](#) in summer 2023

Please note The following information refers to the verification date shown at the bottom of each card. **The Association** is not responsible for any significant changes made by the property after the visit.

Summary

Bathing establishment Fact Sheet	1
Arrival at the facility.....	2
Private/public parking.....	2
Pathway from the parking lot to the main entrance	3
Reception.....	4
Bar/restaurant	4
Internal Pathways and common services.....	6
Internal Pathways	6
Toilet and shower accessible to guests with reduced mobility	6
Changing room	8
Beach.....	9
Children's play area	10
Swimming pool	10
Doctors' Offices/Healthcare Facilities	11



Project carried out with the contribution of the






Arrival at the facility



Private/public parking

Presence of private parking	YES
Type of private car park	gravel
Presence of a parking space reserved for people with disabilities in the private car park	NO
Public parking nearby	YES
Type of public car park	asphalt
Presence of a parking space reserved for people with disabilities in the public car park	YES
	





Pathway from the parking lot to the main entrance

Pathway from the car park to the entrance	flat on a gravel surface that can make it difficult for wheelchair users to move around
There are markers and tactile maps	NO
Usable door/entrance width	more than 90 cm
	





Reception

Umbrella booking system	<input type="checkbox"/> Via web <input checked="" type="checkbox"/> By phone <input checked="" type="checkbox"/> On-site
Presence of multilingual staff	YES
Presence of plant plan with key to services available	NO
Presence of visuo-tactile map	NO
Bulletin board/information panels at an average height of 130 cm in a well-lit area and font size at least 14 dpi with a contrast ratio greater than 4.5:1	NO
The staff attended training courses on welcoming people with different disabilities	NO

Bar/restaurant

Type of venue	Bar/restaurant
Access to the premises	Flat
Usable door/entrance width	more than 90 cm
Bar counter	more than 100 cm
Types of tables	4-legged
Space underneath the tables from the floor	63 cm
Multilingual menu	YES
Menus with large print fonts	YES
Braille menu	NO



Project promoted by



Regione Toscana

Table service for people with disabilities	YES
Availability of gluten-free food	<input checked="" type="checkbox"/> bread <input type="checkbox"/> pasta <input checked="" type="checkbox"/> biscuits <input checked="" type="checkbox"/> ice cream <input type="checkbox"/> Pre-packaged foods
	
	

Project carried out with the contribution of the



**Presidenza del
Consiglio dei Ministri**
Ministro per la disabilità



Internal Pathways and common services

Internal Pathways

<p>Indicate whether the pathways connecting the entrance to the beach are flat or with ramps in addition to those already described</p>	<p>Obstacle-free paths</p>
	

Toilet and shower accessible to guests with reduced mobility

Number of toilets accessible/usable by guests with reduced mobility	1
Access to the premises	Flat
Usable width of the entrance door	cm 87
WC height	54 cm
Open front toilet seat	YES
Support handles	Missing
Flexible hand shower at the side of the toilet	YES
Free space on the sides of the toilet	left 65 cm right 22 cm frontal more than 90 cm






Electric doorbell/phone	YES
Washbasin with space underneath for wheelchair	60 cm
Height from the ground on the bottom edge of the mirror	135 cm
Baby changing table	YES
	
	
Accessible shower available for guests with reduced mobility	Yes outdoor without canopy
Access to the shower room if separated from the toilet room	Flat
Useful width of the door/entrance gate if separated from the toilet room	more than 90 cm





Shower type	with box 93 cm and dimensions 97cm X 93cm
Floor-level shower	YES
Shower chair	missing
Grab bar	missing
Presence of shower head or ups and downs	fixed shower head
Electric doorbell/phone	NO
	

Changing room


Accessible changing room available for guests with reduced mobility	YES
Access to the premises	via ramp length 500 cm, width 100 cm, gradient 4.7 %
Usable door/entrance width	more than 90 cm
Size of the dressing room	width 100 cm and depth 170 cm
Presence of a cot	NO
Coat rack height from the ground	155 cm





Beach

Type of beach	sand
Access to the beach	Flat
Walkway to reach the umbrellas	YES
Type of walkway	wood
Walkway width	100 cm





Removable Platform between the walkway and the umbrella station to facilitate the passage and parking wheelchair	YES
Amphibious beach chair available for helping people with reduced mobility to enjoy swimming (owned by the establishment or by association)	YES
	

Children's play area


Children's play area	missing
----------------------	---------

Swimming pool

The property has a swimming pool	YES
Access to the swimming pool	by foot wash with 6 cm step
Useful width of the entrance gate	more than 90 cm
Access to the pool	via ramp with steps
Bathing aids for guests with reduced mobility	Not present

Project carried out with the contribution of the





Doctors' Offices/Healthcare Facilities

Hospitals near the facility	Ospedale Versilia SS1 Via Aurelia n. 335 55049 Lido di Camaiore LU Tel. 0584/6051
Other Healthcare Facilities	Distretto Sanitario ASL 12 Pietrasanta Via Martiri S. Anna 11 Tel. 05846058823 Croce Verde Via Risorgimento, 1 Forte dei Marmi Tel. 058484013 free dialysis and first aid service for white codes



Project promoted by



Regione Toscana

	<p>Emergency medical service Via Martiri S. Anna Tel. 0584 616774</p> <p>Misericordia Via Mazzini Pietrasanta Tel. 058470055</p> <p>Medical service "San Camillo" Nursing Home Via P.I. da Carrara, 37 Tel. 0584 7391</p> <p>Dialysis service c/o Croce Verde Viale Italico at the corner of Via Risorgimento Forte dei Marmi Tel. 058484013 affiliated with AUSL</p>
--	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

TESTED BY: **Handy Superabile Social Promotion Association in summer 2023**

Project carried out with the contribution of the



**Presidenza del
Consiglio dei Ministri**
Ministro per la disabilità