



## Bathing establishment Fact Sheet

Bathhouse name	ALHAMBRA
Address	Viale Europa 10
City	Viareggio (LU)
Contacts	Phone +39 0584388418
Website	<a href="https://www.bagnoalhambra.it/en">https://www.bagnoalhambra.it/en</a>

**TESTED BY:** [Handy Superabile - Social Promotion Association](#) in summer 2023

**Please note** The following information refers to the verification date shown at the bottom of each card. **The Association** is not responsible for any significant changes made by the facility after the visit

### Summary

Bathing establishment Fact Sheet .....	1
Arrival at the facility .....	2
Private/public parking.....	2
Pathway from the parking lot to the main entrance .....	3
Reception.....	3
Bar/restaurant.....	4
Internal Pathways and common services.....	5
Internal Pathways .....	5
Toilet and shower accessible to guests with reduced mobility .....	6
Changing room .....	8
Beach.....	8
Children's play area .....	10
Swimming pool .....	11
Doctors' Offices/Healthcare Facilities .....	12



Project carried out with the contribution of the





**Arrival at the facility**



**Private/public parking**

Presence of private parking	YES
Type of private car park	gravel
Presence of parking space reserved for people with disabilities	NO
Public parking nearby	YES with parking spaces reserved for the disabled
Type of public car park	Self locking
	
	





**Pathway from the parking lot to the main entrance**

Pathway from the car park to the entrance	Flat
There are markers and tactile maps	NO
Usable door/entrance width	more than 90 cm
	

**Reception**

Umbrella booking system	<input type="checkbox"/> Via web <input checked="" type="checkbox"/> By phone <input checked="" type="checkbox"/> On-site
Presence of multilingual staff	Not detected
Presence of plant plan with key to services available	NO
Presence of visuo-tactile map	NO
Bulletin board/information panels at an average height of 130 cm in a well-lit area	NO






and font size at least 14 dpi with a contrast ratio greater than 4.5:1	
The staff attended training courses on welcoming people with different disabilities	NO

### Bar/restaurant

Type of venue	Bar/restaurant
Access to the premises	by ramp length 900 cm, width >100 cm, slope 6% with handrails on the sides
Usable door/entrance width	more than 90 cm
Bar counter	more than 100 cm
Types of tables	4-legged
Space underneath the tables from the floor	68 cm
Multilingual menu	Not detected
Menus with large print fonts	NO
Braille menu	NO
Table service for people with disabilities	YES
Availability of gluten-free food	<input type="checkbox"/> bread <input type="checkbox"/> pasta <input type="checkbox"/> biscuits <input checked="" type="checkbox"/> ice cream <input checked="" type="checkbox"/> Pre-packaged foods





### **Internal Pathways and common services**

#### **Internal Pathways**

Indicate whether the pathways connecting the entrance to the beach are flat or with ramps in addition to those already described

Obstacle-free paths





**Toilet and shower accessible to guests with reduced mobility**

Number <b>of toilets</b> accessible/usable by guests with reduced mobility	1
Access to the premises	by ramp length 900 cm, width >100 cm, slope 6% with handrails on the sides
Usable width of the entrance door	more than 90 cm
WC height	50 cm
Open front toilet seat	YES
Support handles	on both sides
Flexible hand shower at the side of the toilet	NO
Free space on the sides of the toilet	left more than 90 cm right 23 cm frontal more than 90 cm
Electric doorbell/phone	YES
Washbasin with space underneath for wheelchair	65 cm
Height from the ground on the bottom edge of the mirror	not sufficient for use by a person in a wheelchair
Baby changing table	NO

Project carried out with the contribution of the







	
<p>Accessible <b>shower</b> available for guests with reduced mobility</p>	<p>YES in common with the toilet room</p>
<p>Shower type</p>	<p>open-type</p>
<p>Floor-level shower</p>	<p>YES</p>
<p>Shower chair</p>	<p>missing</p>
<p>Grab bar</p>	<p>YES</p>
<p>Presence of shower head or ups and downs</p>	<p>Ups and downs with the lowest point reachable by a seated person</p>
<p>Electric doorbell/phone</p>	<p>YES</p>
	





### Changing room

Accessible changing room available for guests with reduced mobility	YES
Access to the premises	Flat
Usable door/entrance width	more than 90 cm
Size of the dressing room	width 141 cm and depth 135 cm
Presence of a cot	NO
Coat rack height from the ground	over 140 cm and not accessible to wheelchair users
	

### Beach

Type of beach	sand
Access to the beach	Flat
Walkway to reach the umbrellas	YES
Type of walkway	PVC
Walkway width	100 cm





<p>Removable Platform between the walkway and the umbrella station to facilitate the passage and parking wheelchair</p>	<p>YES</p>
<p>Amphibious beach chair available for helping people with reduced mobility to enjoy swimming (owned by the establishment or by association)</p>	<p>NO</p>





	<p>Shower on the beach flush with the floor on a PVC platform</p>
--	---




**Children's play area**

<p>Children's play area</p>	<p>Not detected</p>
-----------------------------	---------------------





**Swimming pool**

The property has a swimming pool	YES with seawater and hot tub and children's
Access to the swimming pool	by 4 ramps in succession for a total length of 700 cm, width 85 cm, gradient 6 %
Useful width of the entrance gate	more than 90 cm
Access to the pool	with ladder
Bathing aids for guests with reduced mobility	amphibious chair
	
	



Project promoted by



**Regione Toscana**

## Doctors' Offices/Healthcare Facilities

Hospitals near the facility	<b>Ospedale Versilia</b> SS 1, 335, 55049 Camaione LU Telephone: 0584 6051
Other Healthcare Facilities	<b>ASL Health District No. 12</b> Viareggio Piazza Buon Consiglio Viareggio Tel. Phone 0584.6056353 <b>Dialysis service c/o HOSPITAL OF CISANELLO DI PISA</b> Department for dialysis therapy (hemodialysis – peritoneal dialysis) in the period June - September Dialysis Holiday service with availability of n. 6 beds tel. 050 997250 – 997253 – 997256

**TESTED BY: Handy Superabile Social Promotion Association in summer 2023**

Project carried out with the contribution of the



**Presidenza del  
Consiglio dei Ministri**  
Ministro per la disabilità