



---

## Bathing establishment Fact Sheet

Bathhouse name	ERNESTA
Address	Viale Europa 12
City	Viareggio (LU)
Contacts	Tel. +39 0584392188 - <a href="mailto:info@ernesta.it">info@ernesta.it</a>
Website	<a href="http://www.bagnoernesta.com">http://www.bagnoernesta.com</a>

**TESTED BY:** [Handy Superabile - Social Promotion Association](#) in summer 2023

**Please note** The following information refers to the verification date shown at the bottom of each card. **The Association** is not responsible for any significant changes made by the property after the visit.

### Summary

Bathing establishment Fact Sheet .....	1
Arrival at the facility .....	2
Private/public parking .....	2
Pathway from the parking lot to the main entrance .....	2
Reception .....	3
Bar/restaurant .....	4
Internal Pathways and common services .....	5
Internal Pathways .....	5
Toilet and shower accessible to guests with reduced mobility .....	5
Changing room .....	6
Beach .....	7
Children's play area .....	9
Swimming pool .....	9
Doctors' Offices/Healthcare Facilities .....	11

---

Project carried out with the contribution of the





## Arrival at the facility

### Private/public parking

Presence of private parking	YES
Type of private car park	gravel
Presence of parking space reserved for people with disabilities	Not detected
Public parking nearby	YES
Type of public car park	Self locking
	

### Pathway from the parking lot to the main entrance

Pathway from the car park to the entrance	Flat
There are markers and tactile maps	NO
Usable door/entrance width	more than 90 cm



Project promoted by



**Regione Toscana**



## Reception

Umbrella booking system	<input checked="" type="checkbox"/> Via web <input checked="" type="checkbox"/> By phone <input checked="" type="checkbox"/> On-site
Presence of multilingual staff	Not detected
Presence of plant plan with key to services available	NO
Presence of visuo-tactile map	NO
Bulletin board/information panels at an average height of 130 cm in a well-lit area and font size at least 14 dpi with a contrast ratio greater than 4.5:1	NO
The staff attended training courses on welcoming people with different disabilities	NO

Project carried out with the contribution of the



**Presidenza del  
Consiglio dei Ministri**  
Ministro per la disabilità



**Bar/restaurant**

Type of venue	Snack bar
Access to the premises	On the floor only the veranda with tables. To access the bar there are 3 steps that can be climbed with a ramp equipped with a handrail
Usable door/entrance width	more than 90 cm
Bar counter	more than 100 cm
Types of tables	4-legged
Space underneath the tables from the floor	65 cm
Multilingual menu	Not detected
Menus with large print fonts	NO
Braille menu	NO
Table service for people with disabilities	YES
Availability of gluten-free food	<input type="checkbox"/> bread <input type="checkbox"/> pasta <input type="checkbox"/> biscuits <input checked="" type="checkbox"/> ice cream <input checked="" type="checkbox"/> Pre-packaged foods





## Internal Pathways and common services

### Internal Pathways

Indicate whether the pathways connecting the entrance to the beach are flat or with ramps in addition to those already described

Obstacle-free paths

### Toilet and shower accessible to guests with reduced mobility

Number <b>of toilets</b> accessible/usable by guests with reduced mobility	1
Access to the premises	by ramp 600 cm long, > 90 cm wide, slope 7.5 % with handrails on the sides
Usable width of the entrance door	86 cm
WC height	50 cm
Open front toilet seat	YES
Support handles	on both sides
Flexible hand shower at the side of the toilet	NO
Free space on the sides of the toilet	left 20 Cm right more than 90 cm frontal more than 90 cm
Electric doorbell/phone	YES
Washbasin with space underneath for wheelchair	65 cm
Height from the ground on the bottom edge of the mirror	not sufficient for use by a person in a wheelchair
Baby changing table	Not detected
Accessible shower available for guests with reduced mobility	The the establishment has a shower room with a door/space for a guest in a wheelchair; There is an outdoor shower, not



	hot, reachable via a PVC walkway, flush with the floor.
	
	


**Changing room**

Accessible changing room available for guests with reduced mobility	YES
Access to the premises	via ramp 600 cm long, > 90 cm wide, slope 7.5 % (see toilets)
Usable door/entrance width	86 cm

Project carried out with the contribution of the





Size of the dressing room	width 150 cm and depth 148 cm
Presence of a cot	NO
Coat rack height from the ground	over 140 cm and not accessible to wheelchair users
	

## Beach

Type of beach	sand
Access to the beach	Flat
Walkway to reach the umbrellas	YES
Type of walkway	PVC
Walkway width	100 cm



	
<p>Removable Platform between the walkway and the umbrella station to facilitate the passage and parking wheelchair</p>	<p>YES</p>
<p>Amphibious beach chair available for helping people with reduced mobility to enjoy swimming (owned by the establishment or by association)</p>	<p>YES</p>
	





### Children's play area

Children's play area	Accessible to children with reduced mobility
There are games for children with reduced mobility	Not detected
	

### Swimming pool


The property has a swimming pool	YES
Access to the swimming pool	Accessible via 4 ramps interspersed with 3 rest shelves, 83 cm wide, the first two 400 cm long, and the last two 300 cm long. Average gradient 6/7%
Useful width of the entrance gate	86 cm
Access to the pool	with ladder
Bathing aids for guests with reduced mobility	Not present



Project promoted by



**Regione Toscana**



Project carried out with the contribution of the



**Presidenza del  
Consiglio dei Ministri**  
Ministro per la disabilità

Project promoted by



**Regione Toscana**

### **Doctors' Offices/Healthcare Facilities**

Hospitals near the facility	<b>Ospedale Versilia</b> SS 1, 335, 55049 Camaione LU Telephone: 0584 6051
Other Healthcare Facilities	<b>ASL Health District No. 12</b> Viareggio Piazza Buon Consiglio Viareggio Tel. Phone 0584.6056353  <b>Dialysis service c/o HOSPITAL OF CISANELLO DI PISA</b> Department for dialysis therapy (hemodialysis – peritoneal dialysis) in the period June - September Dialysis Holiday service with availability of n. 6 beds tel. 050 997250 – 997253 – 997256

**TESTED BY: Handy Superabile Social Promotion Association in summer 2023**

Project carried out with the contribution of the



**Presidenza del  
Consiglio dei Ministri**  
Ministro per la disabilità