



Bathing establishment Fact Sheet

Bathhouse name	VITTORIO VENETO
Address	Viale Europa 24
City	Viareggio (LU)
Contacts	Phone +39 0584 392118
Website	http://www.bagnovittorioveneto.com/ing

TESTED BY: [Handy Superabile - Social Promotion Association](#) in summer 2023

Please note The following information refers to the verification date shown at the bottom of each card. **The Association** is not responsible for any significant changes made by the property after the visit.

Summary

Bathing establishment Fact Sheet	1
Arrival at the facility.....	2
Private/public parking.....	2
Pathway from the parking lot to the main entrance	3
Reception.....	3
Bar/restaurant	4
Internal Pathways and common services.....	6
Internal Pathways	6
Toilet and shower accessible to guests with reduced mobility	6
Changing room	10
Beach.....	10
Children's play area	12
Swimming pool	12
Doctors' Offices/Healthcare Facilities	13

Project carried out with the contribution of the





Arrival at the facility



Private/public parking

Presence of private parking	YES
Type of private car park	gravel
Presence of parking space reserved for people with disabilities	YES with 2 places reserved for the disabled
Public parking nearby	YES with 1 seat reserved for the disabled
Type of public car park	Self locking





Pathway from the parking lot to the main entrance

Pathway from the car park to the entrance	Flat
There are markers and tactile maps	NO
Usable door/entrance width	more than 90 cm
	

Reception

Umbrella booking system	<input checked="" type="checkbox"/> Via web <input checked="" type="checkbox"/> By phone <input checked="" type="checkbox"/> On-site
Presence of multilingual staff	Not detected
Presence of plant plan with key to services available	NO
Presence of visuo-tactile map	NO
Bulletin board/information panels at an average height of 130 cm in a well-lit area	NO





and font size at least 14 dpi with a contrast ratio greater than 4.5:1	
The staff attended training courses on welcoming people with different disabilities	NO

Bar/restaurant

Type of venue	Bar/restaurant
Access to the premises	via ramp: length 108 + 125 cm, width 120 cm, slope 8%, handrail on the right
Usable door/entrance width	more than 90 cm
Bar counter	less than 100 cm
Types of tables	4-legged
Space underneath the tables from the floor	68 cm
Multilingual menu	Not detected
Menus with large print fonts	NO
Braille menu	NO
Table service for people with disabilities	YES
Availability of gluten-free food	<input checked="" type="checkbox"/> bread <input checked="" type="checkbox"/> pasta <input type="checkbox"/> biscuits <input checked="" type="checkbox"/> ice cream <input type="checkbox"/> Pre-packaged foods



Project promoted by



Regione Toscana



Project carried out with the contribution of the



**Presidenza del
Consiglio dei Ministri**
Ministro per la disabilità




Internal Pathways and common services

Internal Pathways

Indicate whether the pathways connecting the entrance to the beach are flat or with ramps in addition to those already described

obstacle-free paths. Along the internal paths there are relaxation areas with armchairs, an area equipped with children's games and a large whirlpool tub that can be reached on the flat but with access via a bench without a lift





Toilet and shower accessible to guests with reduced mobility

Number of toilets accessible/usable by guests with reduced mobility	2
Access to the first room	The first toilet described is adjacent to the bar restaurant and can be reached by the same ramp: length 108 + 125 cm, width 120 cm, slope 8%, handrail on the right
Usable width of the entrance door	more than 90 cm
WC height	50 cm





Open front toilet seat	YES
Support handles	on both sides
Flexible hand shower at the side of the toilet	NO
Free space on the sides of the toilet	left 25 Cm right more than 90 cm frontal more than 90 cm
Electric doorbell/phone	YES
Washbasin with space underneath for wheelchair	73 cm
Height from the ground on the bottom edge of the mirror	not sufficient for use by a person in a wheelchair
Baby changing table	YES
 reduced mobility	
Access to the shower room if separated from the toilet room	Flat
Useful width of the door/entrance gate if separated from the toilet room	more than 90 cm
Shower type	open-type
Floor-level shower	YES
Shower chair	missing
Grab bar	YES





Presence of shower head or ups and downs	fixed shower head
Electric doorbell/phone	NO
	

Access to the second room	The second toilet described is located in the common area adjacent to the shower, changing room and can be reached via a ramp: length 332 cm, width 100 cm, slope 7 %
Usable inlet port width	more than 90 cm
WC height	50 cm
Toilet seat with open front tooth	YES
Support handles	to the left of the toilet
Flexible hand shower at the side of the toilet	YES
Free space on the sides of the toilet	left 85 cm right 24 cm frontal more than 90 cm
Electric doorbell/phone	YES
Washbasin with space underneath for wheelchair storage	78 cm
Height from the ground on the bottom edge of the mirror	sufficient for use by wheelchair users
Baby changing table	NO







	
<p>Accessible shower available for guests with reduced mobility</p>	<p>YES in common with the toilet room</p>
<p>Shower type</p>	<p>open-type</p>
<p>Floor-level shower</p>	<p>YES</p>
<p>Shower chair</p>	<p>Stool type without armrests</p>
<p>Grab bar</p>	<p>missing</p>
<p>Presence of shower head or ups and downs</p>	<p>fixed shower head</p>
<p>Electric doorbell/phone</p>	<p>NO</p>
	





Changing room

Accessible changing room available for guests with reduced mobility	YES
Access to the premises	via a removable ramp to overcome 3 steps at the entrance to the changing room. The staff is available to place the ramp to allow the guest in wheelchair to reach the changing room
Usable door/entrance width	more than 90 cm
Size of the dressing room	width 175 cm and depth 180 cm
Presence of a cot	YES
Coat rack height from the ground	130 cm
	

Beach

Type of beach	sand
Access to the beach	Flat
Walkway to reach the umbrellas	YES
Type of walkway	PVC
Walkway width	100 cm





	
<p>Removable Platform between the walkway and the umbrella station to facilitate the passage and parking wheelchair</p>	<p>YES</p>
<p>Amphibious beach chair available for helping people with reduced mobility to enjoy swimming (owned by the establishment or by association)</p>	<p>YES</p>
	





Children's play area

<p>Children's play area</p>	<p>inaccessible to children with reduced mobility due to sandy bottom</p>
	<p style="text-align: center;">Spacious but on a sandy background</p>

Swimming pool

<p>The property has a swimming pool</p>	<p>NO</p>
---	-----------



Project promoted by



Regione Toscana

Doctors' Offices/Healthcare Facilities

Hospitals near the facility	Ospedale Versilia SS 1, 335, 55049 Camaiole LU Telephone: 0584 6051
Other Healthcare Facilities	ASL Health District No. 12 Viareggio Piazza Buon Consiglio Viareggio Tel. Phone 0584.6056353 Dialysis service c/o HOSPITAL OF CISANELLO DI PISA Department for dialysis therapy (hemodialysis – peritoneal dialysis) in the period June - September Dialysis Holiday service with availability of n. 6 beds tel. 050 997250 – 997253 – 997256

TESTED BY: Handy Superabile Social Promotion Association in summer 2023

Project carried out with the contribution of the



**Presidenza del
Consiglio dei Ministri**
Ministro per la disabilità