



Bathing establishment Fact Sheet

Bathhouse name	PRIMAVERA
Address	Via G.Barellai,69
City	Viareggio (Lu)
Contacts	Tel. 0584 53457
Website	http://bagnoprimavera.com/

TESTED BY: [Handy Superabile - Social Promotion Association](#) in summer 2023

Please note The following information refers to the verification date shown at the bottom of each card. **The Association** is not responsible for any significant changes made by the property after the visit.

Summary

Bathing establishment Fact Sheet	1
Arrival at the facility	2
Private/public parking.....	2
Pathway from the parking lot to the main entrance	2
Reception.....	2
Bar/restaurant	3
Internal Pathways and common services.....	4
Internal Pathways	4
Toilet and shower accessible to guests with reduced mobility	5
Changing room	7
Beach.....	7
Children's play area	8
Swimming pool	9
Doctors' Offices/Healthcare Facilities	10



Project carried out with the contribution of the





Arrival at the facility

Private/public parking

Presence of private parking	NO
Public parking nearby	YES with parking spaces reserved for the disabled
Type of public car park	asphalt
	

Pathway from the parking lot to the main entrance

Pathway from the car park to the entrance	Flat
There are markers and tactile maps	NO
Usable door/entrance width	more than 90 cm

Reception





Umbrella booking system	<input type="checkbox"/> Via web <input checked="" type="checkbox"/> By phone <input checked="" type="checkbox"/> On-site
Presence of multilingual staff	Not detected
Presence of plant plan with key to services available	NO
Presence of visuo-tactile map	NO
Bulletin board/information panels at an average height of 130 cm in a well-lit area and font size at least 14 dpi with a contrast ratio greater than 4.5:1	NO
The staff attended training courses on welcoming people with different disabilities	NO

Bar/restaurant

Type of venue	Refreshment point
Access to the premises	The bar is accessible via 4 steps while the veranda restaurant is accessible on the floor
Usable door/entrance width	more than 90 cm
Bar counter	more than 100 cm
Types of tables	with central support
Space underneath the tables from the floor	77 cm
Multilingual menu	Not detected
Menus with large print fonts	NO
Braille menu	NO
Table service for people with disabilities	YES
Availability of gluten-free food	<input type="checkbox"/> bread <input type="checkbox"/> pasta <input type="checkbox"/> biscuits <input type="checkbox"/> ice cream <input type="checkbox"/> Pre-packaged foods



Project promoted by



Regione Toscana



Internal Pathways and common services

Internal Pathways

Project carried out with the contribution of the



Presidenza del
Consiglio dei Ministri
Ministro per la disabilità



Indicate whether the pathways connecting the entrance to the beach are flat or with ramps in addition to those already described	Obstacle-free paths
--	---------------------

Toilet and shower accessible to guests with reduced mobility

Number of toilets accessible/usable by guests with reduced mobility	1
Access to the premises	via ramp: length 380 cm, width 120 cm, slope 13% and handrail on the left
Usable width of the entrance door	84 cm
Toilet height	50 cm
Open front toilet seat	YES
Support handles	to the left of the toilet
Flexible hand shower at the side of the toilet	YES
Free space on the sides of the toilet	left more than 90 cm right 28 cm frontal more than 90 cm
Electric doorbell/phone	YES
Washbasin with space underneath for wheelchair	77 cm
Height from the ground on the bottom edge of the mirror	120 cm
Baby changing table	NO






<p>Accessible shower available for guests with reduced mobility</p>	<p>YES in common with the toilet room</p>
<p>Shower type</p>	<p>open-type</p>
<p>Floor-level shower</p>	<p>YES</p>
<p>Shower chair</p>	<p>wall-mounted folding</p>
<p>Grab bar</p>	<p>YES</p>
<p>Presence of shower head or ups and downs</p>	<p>Sliding rails with lowest point height at 140 cm and taps at 110 cm</p>
<p>Electric doorbell/phone</p>	<p>YES</p>





Changing room

Accessible changing room available for guests with reduced mobility	YES
Access to the premises	T Ramite ramp Length A few years ago 380 cm, width A few years ago 120 cm, pendenza 13% and handrail on the left
Usable door/entrance width	84 cm
Size of the dressing room	width 150 cm and depth 208 cm
Presence of a cot	NO
Coat rack height from the ground	180 cm
	

Beach

Type of beach	sand
Access to the beach	By means of 1 step of 7 cm that can be overcome by lifting the walkway
Walkway to reach the umbrellas	YES
Type of walkway	PVC





Walkway width	90 cm
	
Removable Platform between the walkway and the umbrella station to facilitate the passage and parking wheelchair	YES
Amphibious beach chair available for helping people with reduced mobility to enjoy swimming (owned by the establishment or by association)	YES
	

Children's play area





Children's play area	missing
----------------------	---------

Swimming pool

The property has a swimming pool	YES
Access to the swimming pool	Flat
Useful width of the entrance gate	more than 90 cm
Access to the pool	via ramp with 3 steps and handrails
Bathing aids for guests with reduced mobility	amphibious chair



Project promoted by



Regione Toscana

Doctors' Offices/Healthcare Facilities

Hospitals near the facility	Ospedale Versilia SS 1, 335, 55049 Camaione LU Telephone: 0584 6051
Other Healthcare Facilities	ASL Health District No. 12 Viareggio Piazza Buon Consiglio Viareggio Tel. Phone 0584.6056353 Dialysis service c/o HOSPITAL OF CISANELLO DI PISA Department for dialysis therapy (hemodialysis – peritoneal dialysis) in the period June - September Dialysis Holiday service with availability of n. 6 beds tel. 050 997250 – 997253 – 997256

TESTED BY: **Handy Superabile Social Promotion Association in summer 2023**

Project carried out with the contribution of the



Presidenza del
Consiglio dei Ministri
Ministro per la disabilità