



Bathing establishment fact sheet

Name of bathing establishment	FLORINDO
Address	VIA BARELLAI 67
City	VIAREGGIO (LU)
Contacts	+39 392 982 0788
Website	NOT DETECTED

TESTED BY: [Handy Superabile Social Promotion Association](#) in summer 2024

Please note The following information refers to the date of verification shown at the bottom of each sheet. **The Association** is not responsible for any significant changes made by the property after the visit.

Summary

Bathing establishment fact sheet.....	1
Arrival at the property.....	2
Private/public parking.....	2
Pathway from the car park to the entrance	2
Reception.....	3
Bar/restaurant	3
Internal pathways and common services	5
Internal pathways.....	5
Changing room	7
Beach.....	7
Swimming pool	8
Medical practices/healthcare facilities.....	10

Project carried out with the contribution of the





Arrival at the property

Private/public parking

Public parking nearby	YES
Type of public parking floor	asphalt
Presence of parking space reserved for people with disabilities	SI num.1
	

Pathway from the car park to the entrance

Path from the car park to the entrance	flat
Distance from parking to entrance	50/100 meters
Type of trail surface	asphalt
There is an accessible entrance	YES main entrance
How to access the site	<input checked="" type="checkbox"/> via ramp DI CONNECTION single length 80 cm, width 100 cm, slope 10%





There are indicators and tactile maps	NO
Useful width of door/entrance gate	Above 90 cm

Reception

Umbrella booking system	<input type="checkbox"/> Via the web <input checked="" type="checkbox"/> By phone <input type="checkbox"/> On-site
Presence of multilingual staff	YES
Presence of plant map with legend of services present	NO
Presence of visual-tactile map	NO
Bulletin board/information panels with an average height of 130 cm in a well-lit area and a font size of at least 14 dpi with a contrast ratio greater than 4.5:1	YES
The staff followed a training course on welcoming people with different disabilities	NO

Bar/restaurant

Type of venue	Snack bar
How to access the premises	<input checked="" type="checkbox"/> via ramp single length 520 cm, width 95 cm, slope 9.5 %, handrails on both sides
Useful width of door/entrance gate	Above 90 cm
Bar counter	Above 100 cm
Types of tables	with central support
Space under floor tables	70 cm
Availability of high chairs for babies	NO

Project carried out with the contribution of the





Multilingual menu	YES
Large print menus	NO
Braille menu	NO
Table service for people with disabilities	YES
Availability of dedicated kitchens/separate dishes for celiacs/food intolerant	YES separate tableware
Availability of foods for celiacs	<input checked="" type="checkbox"/> bread and, pasta





Internal pathways and common services

Internal pathways

Indicate whether the entrance-beach connection routes are flat or with ramps in addition to those already described	Flat
Number of accessible toilets for guests with reduced mobility	1
How to access the premises	<input checked="" type="checkbox"/> via ramp single length 570 cm, width 93 cm, slope 10 %, handrail ad entrambi i lati
Usable width of the entrance door	82 cm
Type of door	with door that can be opened outwards
Type of handle	lever
Toilet height	50 cm
Toilet seat with open front tooth	YES
Support handles	on both sides
Flexible shower on the side of the toilet	YES
Free space on the sides of the toilet	left 22 cm right Above 90 cm frontal 50 cm
Electric doorbell/telephone	YES
Washbasin with space underneath for wheelchair approach	Above 70 cm
Height from the ground lower edge mirror	not sufficient for use by a person in a wheelchair
Baby changing table	Not detected





<p>Accessible shower available for guests with reduced mobility</p>	<p>YES in common with the toilet room</p>
<p>Type of shower</p>	<p>open type</p>
<p>Floor-level shower</p>	<p>YES</p>
<p>Shower chair</p>	<p>missing</p>
<p>Support handle</p>	<p>YES</p>
<p>Presence of shower head or sliding rails</p>	<p>Fixed shower head</p>
<p>Electric doorbell/telephone</p>	<p>YES</p>





Changing room

Changing room accessible to guests with reduced mobility available	YES
Access to the premises	Via the same toilet ramp
Useful width of door/entrance gate	82 cm
Type of door	with door that can be opened outwards
Type of handle	lever
Locker room size	Width 122 cm and depth 176 cm
Presence of cot	NO
Coat rack height from the ground	180 cm
	

Beach

Type of beach	sand
Beach access	flat
Walkway to reach the umbrellas	YES
Type of walkway	PVC
Width of the walkway	100 cm





<p>Also removable platform between the walkway and the umbrella station to facilitate the passage and parking with the wheelchair</p>	<p>YES</p>
<p>Amphibious chair available for bathing people with reduced mobility owned or through bathing associations</p>	<p>YES</p>

Swimming pool

<p>The property has a swimming pool</p>	<p>for seawater adults</p>
<p>Pool with heated water</p>	<p>NO</p>
<p>Access to the swimming pool</p>	<p>via the same toilet ramp</p>
<p>Useful width of the entrance gate</p>	<p>Above 90 cm</p>
<p>Access to the pool</p>	<p>with ladder</p>

Project carried out with the contribution of the





Bathing aids for guests with reduced mobility	not present
Height of the pool edge-water level	infinity
In the pool area there is a shower	Not detected
Eventual notes	The pool is 140 cm deep





Medical practices/healthcare facilities

Hospitals near the property	Versilia Hospital Via SS 1 335 Lido di Camaiore (LU) Tel +39 0584 6051 Distance 5.7 km Civil Hospital, UsI Toscana nord ovest presidio territoriale G. Tabarracci Via A. Fratti 530 Viareggio (LU) Tel +39 0584 6059320/6059219
Other healthcare facilities	Cisanello Hospital Pisa. Distance 23 km In the period June-September holiday dialysis service with availability of n. 6 beds; The treatments will be divided into three days a week (Monday, Wednesday and Friday) in the evening from 18.00 to 24.00 Phone +39 050 997250/997253/997256 call from 8.00 a.m. to 2.00 p.m. Email nefrotrap.pisa@ao-pisa.toscana.it
	Croce Verde Viareggio Corso G. Garibaldi 208 Viareggio (LU) Tel +39 0584 30885

TESTED BY: [Handy Superabile Social Promotion Association](#) in summer 2023

